

Distributed by: Reliant EMC LLC, +1 408 916-575 0, info@reliantemc.com, www.reliantemc.com

INSTRUCTION MANUAL for COMBINATION WAVE SURGE GENERATOR

Model: SGIEC-645



REV071917



Table of Contents

1.0	Inti	roductio	on	6
2.0	Pro	ducts A	Available from Com-Power	7
3.0	Pro	duct In	formation	8
	3 1	Incomi		g
	2.1	Daaka		0
	3.Z	FUCKU		0
	3.3	Produc	ct safety information	
		3.3.1	Product Hazard Symbols Definitions	
		3.3.Z	Conord Safety Instructions	
		331	Safety Guidelines During Surge Testing	
		335	Safety Concerns During Surge Testing	10
	3.4	Produc	t Features	
	3.5	Produc	t Specifications	
40	Set	Hina un	the SGIFC-645	15
	4.1	Input P	ower Line Ports	15
		4.1.1	SGIEC-645 System Power Input Port	15
			4.1.1.1 System Power Input Port Fuse	15
		4.1.2	Equipment Under Test (EUT) Power Input Port	16
			4.1.2.1 Turning ON/OFF EUT Power – LOCAL Control	
			4.1.2.2 Turning ON/OFF EUT Power – REMOTE Control	
	4.2	Input/C	Jutput Ports	
		4.2.1	Satety Interlock Port	
		4.2.2	Fiber Optic Port	
	12	Monito	4.2.2.1 Setting up the Remote Interface	20
	4.0	1001110 4 2 1		·····∠1
		4.3.1	Sync Oulput Foll (Sync. O/F)	21 21
		4.3.2 4 3 3	Current Monitor Port (Imag)	21
	ΔΛ	Surae (Generator Outout Ports	21 22
	7.7	Juige		
		441	Auxiliary (A/B) Surge Output Ports	23

Distributed by: Reliant EMC LLC, +1 408 916-5750, info@reliantemc.com, www.reliantemc.com

- TABLE OF CONTENTS -

COM-POWER CORPORATION

5.0 0	Calibrati	on of Surge Output Waveforms	24		
5.	.1 Recc	mmended Test Equipment			
5.	.2 Surge	Surge Waveform Measurements			
	5.2.1	Open Circuit Voltage Measurements	24		
	5.2.2	Short Circuit Current Measurements	24		
5.	.3 Meas	urement Connections	25		
5.	.4 Surge	Waveform Requirements (Generator Output)			
	5.4.1	Open Circuit Surge Voltage Waveforms – Generator Output			
		5.4.1.1 Measurement of Voltage Waveform Parameters			
		5.4.1.2 Example calculations for Voltage Waveform Parameters			
	5.4.2	Short Circuit Surge Current Waveforms			
		5.4.2.1 Measurement of Current Waveform Parameters	31		
		5.4.2.2 Example calculations for Current Waveform Parameters			
5.	.5 Surge	Waveform Requirements at CDN Outputs			
	5.5.1	CDN for Power Lines -1.2/50 µs, 8/20 µs Waveform			
	5.5.2	CDN for Data Lines - 1.2/50 µs, 8/20 µs Waveform			
	5.5.3	CDN for Telecom Lines - 1.2/50 µs, 8/20 µs Waveform			
-	5.5.4	CDN for Telecom Lines – 10/700 µs, 5/320 µs Waveform			
5.	.6 Com	bined Reference Table of Waveform Limits			
6.0 (Confrolli	ng the SGIEC-645 via its Front Panel	40		
6.	.1 Initial	Startup	40		
6. 6.	.1 Initial .2 Self-T	Startup est	40 41		
6. 6. 6.	.1 Initial .2 Self-T .3 Quic	Startup est < Menu Access Option	40 41 42		
6. 6. 6.	.1 Initial .2 Self-T .3 Quict .4 Surge	Startup est < Menu Access Option 9 Setup Menu Screen	40 41 42 43		
6. 6. 6.	.1 Initial .2 Self-T .3 Quick .4 Surge 6.4.1	Startup est Menu Access Option Setup Menu Screen Surge Setup Menu Navigation/Operation	40 41 42 43 45		
6. 6. 6.	.1 Initial .2 Self-T .3 Quict .4 Surge 6.4.1	Startup est Menu Access Option Se Setup Menu Screen Surge Setup Menu Navigation/Operation 6.4.1.1 Menu Navigation	40 41 42 43 45 45		
6. 6. 6.	.1 Initial .2 Self-T .3 Quict .4 Surge 6.4.1	Startup est Menu Access Option Setup Menu Screen Surge Setup Menu Navigation/Operation	40 41 42 43 45 45 45		
6. 6. 6.	.1 Initial .2 Self-T .3 Quict .4 Surge 6.4.1	Startup est Menu Access Option e Setup Menu Screen Surge Setup Menu Navigation/Operation 6.4.1.1 Menu Navigation 6.4.1.2 Modifying Non-Numeric Surge Parameter Fields 6.4.1.3 Modifying Numeric Surge Parameter Fields	40 41 42 43 45 45 45 45		
6. 6. 6.	.1 Initial .2 Self-T .3 Quick .4 Surge 6.4.1	Startup est Menu Access Option Se Setup Menu Screen Surge Setup Menu Navigation/Operation	40 41 42 43 43 45 45 45 45 45		
6. 6. 6.	.1 Initial .2 Self-T .3 Quict .4 Surge 6.4.1	Startup est Menu Access Option Setup Menu Screen Surge Setup Menu Navigation/Operation 6.4.1.1 Menu Navigation 6.4.1.2 Modifying Non-Numeric Surge Parameter Fields 6.4.1.3 Modifying Numeric Surge Parameter Fields Surge Setup Menu Items 6.4.2.1 Surge Waveform	40 41 42 43 45 45 45 45 45 46 46		
6. 6. 6.	.1 Initial .2 Self-T .3 Quicl .4 Surge 6.4.1	Startup est Menu Access Option Setup Menu Screen Surge Setup Menu Navigation/Operation 6.4.1.1 Menu Navigation 6.4.1.2 Modifying Non-Numeric Surge Parameter Fields 6.4.1.3 Modifying Numeric Surge Parameter Fields Surge Setup Menu Items 6.4.2.1 Surge Waveform 6.4.2.2 Surge Coupling	40 41 42 43 43 45 45 45 45 45 45 45 45 46 46 46		
6. 6. 6.	.1 Initial .2 Self-T .3 Quict .4 Surge 6.4.1	Startup est Menu Access Option Surge Setup Menu Screen Surge Setup Menu Navigation/Operation 6.4.1.1 Menu Navigation 6.4.1.2 Modifying Non-Numeric Surge Parameter Fields 6.4.1.3 Modifying Numeric Surge Parameter Fields Surge Setup Menu Items 6.4.2.1 Surge Waveform 6.4.2.2 Surge Coupling 6.4.2.3 Source Impedance	40 41 42 43 43 45 45 45 45 45 45 45 46 46 46 46		
6. 6. 6.	.1 Initial .2 Self-T .3 Quicl .4 Surge 6.4.1	Startup est Menu Access Option Sestup Menu Screen Surge Setup Menu Navigation/Operation 6.4.1.1 Menu Navigation 6.4.1.2 Modifying Non-Numeric Surge Parameter Fields 6.4.1.3 Modifying Numeric Surge Parameter Fields Surge Setup Menu Items 6.4.2.1 Surge Waveform 6.4.2.2 Surge Coupling 6.4.2.3 Source Impedance 6.4.2.4 Surge Output Voltage	40 41 42 43 43 45 45 45 45 45 45 45 45 46 46 46 46 46 46 47		
6. 6. 6.	.1 Initial .2 Self-T .3 Quicl .4 Surge 6.4.1	Startupest est Menu Access Option Surge Setup Menu Screen Surge Setup Menu Navigation/Operation 6.4.1.1 Menu Navigation 6.4.1.2 Modifying Non-Numeric Surge Parameter Fields 6.4.1.3 Modifying Numeric Surge Parameter Fields Surge Setup Menu Items 6.4.2.1 Surge Waveform 6.4.2.2 Surge Coupling 6.4.2.3 Source Impedance 6.4.2.4 Surge Output Voltage 6.4.2.5 Number of Surges 6.4.2.4 Time Between Surger	40 41 42 43 45 45 45 45 45 45 45 45 46 46 46 46 46 46 47 47		
6. 6. 6.	.1 Initial .2 Self-T .3 Quict .4 Surge 6.4.1	Startup est	40 41 42 43 43 45 45 45 45 45 45 45 45 45 46 46 46 46 46 46 46 47 47 47		
6. 6. 6.	.1 Initial .2 Self-T .3 Quicl .4 Surge 6.4.1	Startupest Menu Access Option	40 41 42 43 45 45 45 45 45 45 45 46 46 46 46 46 46 46 47 47 47 47 47 48 48		
6. 6. 6.	.1 Initial .2 Self-T .3 Quict .4 Surge 6.4.1	Startupest	40 41 42 43 45 45 45 45 45 45 45 45 46 46 46 46 46 46 46 47 47 47 47 47 47 48 48 48 49		
6. 6. 6.	.1 Initial .2 Self-T .3 Quicl .4 Surge 6.4.1	Startup est	40 41 42 43 45 45 45 45 45 45 46 46 46 46 46 46 46 47 47 47 47 47 47 47 47 47 47 47 47 47		
6. 6. 6.	.1 Initial .2 Self-T .3 Quict .4 Surge 6.4.1	Startup	40 41 42 43 45 45 45 45 45 45 45 46 46 46 46 46 46 46 46 46 46 46 46 47 47 47 47 47 47 47 47 47 47 47 49 49 49		



			6.4.2.10	Save Test		50
7.0	Tra	nsWare	-645™ S	oftware		51
	7.1	Main So	creen			51
		7.1.1	Menu Bar			52
			7.1.1.1	File Menu		52
			7.1.1.2	Connect Dev	vice Menu	53
			7.1.1.3	Help Menu		53
		7.1.2	Tool Bar			
		7.1.3	Sequenci	ng Panel		54
			7.1.3.1	User-defined	Surge Test Parameters	55
		7.1.4	Task Optio	ons Panel		56
			7.1.4.1	Sequence Ec	diting Functions	57
			7.1.4.2	Logging Opt	ions	58
		7.1.5	Sequence	e Wizard		60
			7.1.5.1	Surge Wavef	orm	61
			7.1.5.2	Coupling		61
			7.1.5.3	Test Time		61
			7.1.5.4	EUT Power Co	onfiguration	62
			7.1.5.5	Coupling Mc	des	63
			7.1.5.6	Impedance		64
			7.1.5.7	Test Voltage	(s)	64
				7.1.5.7.1	Creating Test Voltage(s) List from Discrete Values	65
				7.1.5.7.2	Creating Test Voltage(s) List using an Incremental List	65
				7.1.5.7.3	Common Mode vs Differential Mode Surge Test Levels	66
			7.1.5.8	Phase Synch	ronization	67
				7.1.5.8.1	Creating Phase Angle List using Discrete Values	68
				7.1.5.8.2	Creating Phase Angle List using Incremental List	68
				7.1.5.8.3 I	Phase Synch – N to PE Coupling Mode	69
			7.1.5.9	Polarity		70
			7.1.5.10	Number of Su	Jrges	70
			7.1.5.11	Time Betwee	n Surges	71
			7.1.5.12	Sequence O	rder Priority	71
			7.1.5.13	Sequence W	izard Surge Parameter Summary	73
			7.1.5.14	Preview Sequ	Jence Button	73
			7.1.5.15	Create Sequ	ence Button	73
		7.1.6	Controls F	ane l		74
		7.1.7	Remote C	Connection St	atus Bar	75
8.0	Wo	arranty	••••••	•••••		76

- TABLE OF CONTENTS -



List of Figures

FIGURE 1 -	Product Features – Front Panel	11
FIGURE 2 -	Product Features – Rear Panel	12
FIGURE 3 -	Product Dimensions	14
FIGURE 4 -	Accessing the Input Power Fuse	15
FIGURE 5 -	Wiring Procedure for EUT Power Input Plug	16
FIGURE 6 -	Safety Interlock Connector Pin-Out & Ext. Switch Connection	19
FIGURE 7 -	Remote Interface Setup Example	20
FIGURE 8 -	Connection to External CDN via Auxiliary (A/B) Ports	23
FIGURE 9 -	EUT Connection to SGIEC-645 for Powerline Surge(s)	23
FIGURE 10 -	Example of Probe Connections at Auxiliary Output Port	25
FIGURE 11 -	Example of Probe Connections at Internal CDN Output Port	25
FIGURE 12 -	1.2/50 µs, 8/20 µs - Open Circuit Voltage Wave Shape	27
FIGURE 13 -	10/700 µs, 5/320 µs - Open Circuit Voltage Wave Shape	27
FIGURE 14 -	1.2/50 µs, 8/20 µs - Short Circuit Current Wave Shape	30
FIGURE 15 -	10/700 $\mu s,5/320~\mu s$ - Short Circuit Current Wave Shape	30
FIGURE 16 -	Surge Waveform Selection on Surge Setup Menu	43
FIGURE 17 -	Summary of Surge Parameters Options for 1.2/50 µs Wave	44
FIGURE 18 -	Summary of Surge Parameter Options for 10/700 µs Wave	44
FIGURE 19 -	Main Screen – TransWare-645™ Software	51
FIGURE 20 -	Sequence Wizard Screen	60

- LIST OF FIGURES -



1.0 Introduction

This manual includes descriptions of front and rear panel ports, controls and indicators; product specifications, safety precautions, operational instructions and warranty information and guidelines and instructions for its proper usage.

Information contained in this manual is the property of Com-Power Corporation. It is issued with the understanding that the material may not be reproduced or copied without the express written permission of Com-Power.



SECTION 1 - INTRODUCTION



Products Available from Com-Power 2.0



Antennas



Comb Generators



Networks (ISN)



Preamplifiers



Transient Limiters



Antenna Kits



Current Probes



Impedance Stabilization Line Impedance Stabilization Networks (LISN)

Power Amplifiers

1

Turntables



Absorbing Clamps



Emissions Test Systems



Antenna Masts



Spectrum Analyzers





Antenna Tripods



Coupling/Decoupling Networks (CDN)



Conducted Immunity Test Systems



Near-Field Probe Sets



Product Safety Test Equipment



Telecom Test Systems



SECTION 2 - PRODUCTS AVAILABLE FROM COM-POWER

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



3.0 Product Information

3.1 Incoming Inspection

WARNING – To avoid possibility of electrical shock, do not apply power to the Com-Power SGIEC-645 if there is any evidence of shipping damage. If shipping damage to the product or any of the accessories is suspected, or if the package contents are not complete, contact Com-Power or your Com-Power distributor.

Please check the contents of the shipment against the package inventory in section 3.2 to ensure that you have received all applicable items.

3.2 Package Inventory

STANDARD ITEMS:

- ✓ SGIEC-645 Combination Wave Surge Generator
- Safety Interlock Port Key (4-pin, 7mm, Push-Pull plug)
- 4-pin, 7mm, Push-Pull Plug Connector (for optional connection of remote switch for safety interlock)
- IEC Power Cord (NEMA 5-15R-male to IEC C13-female) (for SGIEC-645 system power input)
- ABB 216C6 16A IP44 Connector (for SGIEC-645 connection to supply for EUT power)
- ✓ Calibration Certificate and Data

OPTIONAL ITEMS:

- ✓ OTA-232 Optical Transreceiver Adapter
 - ✓ Fiber Optic Cable (Duplex Latching POF Connector at each end)
 - ✓ USB Cable (USB Type A to USB Type B)
- ✓ TransWare-645[™] PC Software on CD (for remote operation of generator via fiber optic interface)

SECTION 3 - PRODUCT INFORMATION

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



3.3 Product Safety Information

3.3.1 Product Hazard Symbols Definitions

The hazard symbols appearing on the product exterior are defined below.



The yellow triangle with an exclamation mark indicates the presence of important operating and/or maintenance (servicing) instructions in the literature accompanying the product.

The yellow triangle with a lightning bolt indicates an alert to the user that uninsulated **dangerous voltages** are present within the product enclosure and on output connectors. These voltages may be of sufficient magnitude to constitute a risk of electric shock to persons.

3.3.2 Product Warning/Caution Statements

WARNING: TO PREVENT ELECTRIC SHOCK, DO NOT OPEN COVER. SERVICING ONLY BY QUALIFIED PERSONNEL. NO USER SERVICEABLE PARTS INSIDE

CAUTION: FOR CONTINUED PROTECTION AGAINST RISK OF FIRE, REPLACE ONLY WITH THE SAME TYPE AND RATING OF FUSE.

3.3.3 General Safety Instructions

The following safety instructions have been included in compliance with safety standard regulations. Please read them carefully.

- **READ AND RETAIN INSTRUCTIONS** Read all safety and operating instructions before operating the instrument. Retain all instructions for future reference.
- HEED WARNINGS Adhere to all warnings on the instrument and operating instructions.
- FOLLOW INSTRUCTIONS Follow all operating and use instructions.
- WATER AND MOISTURE Do not use the instrument near water.
- WALL OR CEILING MOUNTING Do not mount the instrument on a wall or ceiling.
- VENTILATION The instrument should be situated so that its location or position does not interfere with its proper ventilation. Do not install in a cabinet or in other situations that may impede the flow of air through the ventilation openings.
- **HEAT** The instrument should be situated away from heat sources such as heat registers or other instruments which produce heat.
- **POWER SOURCES** Connect the instrument only to the type of power source described in the operating instructions or as marked on the instrument.
- **GROUNDING AND POLARIZATION** Take precautions to insure that the grounding of the instrument is not defeated. Operate only with a grounded power cord.
- **POWER CORD PROTECTION** Place power supply cords so that they are not likely to be walked on or pinched by items placed on them or against them.
- CLEANING Clean the instrument only as recommended by the manufacturer.
- NON-USE PERIODS Unplug the power cords of the instrument when it will be left unused for a long period of time.
- **OBJECT AND LIQUID ENTRY** Take care that objects do not fall and that liquids are not spilled into the enclosure through openings.
- **DEFECTS AND ABNORMAL STRESS** Whenever it is likely that the normal operation has been impaired, make the equipment inoperable and secure it against further operation.
- DAMAGE REQUIRING SERVICE Instrument should be serviced by qualified personnel when:
 The power supply cord or the plug has been damaged.
 - Objects have fallen or liquid has been spilled into the instrument.
 - The instrument has been exposed to rain.
 - The instrument does not appear to operate normally.
 - The instrument has been dropped, or the enclosure has been damaged.
- SITTING OR CLIMBING Do not sit or climb upon the instrument or use it as a step or ladder.

SECTION 3 - PRODUCT INFORMATION

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



3.3.4 Safety Guidelines During Surge Testing

- Do not work alone.
- Do not use the equipment in conditions other than reasonable laboratory conditions. There should be no condensing humidity or water standing on the floor or work surfaces; there should not be significant dust or other contamination.
- Ensure that no one is touching the equipment under test (EUT) during the test or immediately after the test until AC power to the EUT has been turned off.
- Ensure that there is a barrier to act as protection in case the equipment under test explodes. The barrier should be interlocked to prevent surging and to disconnect all AC if the barrier is removed.
- The equipment under test must be surrounded by sufficient insulating material to withstand twice the surge voltage. Consider distance to the floor or table and walls if air is the insulating material.
- Ensure that the proper supply mains voltages are applied to both Com-Power equipment and to the equipment under test, and that the AC branch circuit is capable of supplying the current.
- The ground (protective earth), neutral and phase lines of the AC supply to the equipment under test (EUT) and Com-Power equipment must be connected properly. Do not defeat the protective earth connection.
- When surging a powered EUT, the mains supply to the equipment under test must be capable of handling the potential AC fault current (e.g. do not use a UPS to power the EUT).
- Never surge an AC mains line other than through the EUT output connector or compatible Com-Power single-phase or three-phase coupler.
- Use only equipment which is designed to be safe for the test being performed.
- Do not test in a potentially explosive atmosphere (e.g. where there are gas fumes).
- Never use equipment that is operating in a strange manner, or that shows clear indication of abuse.
- If probes are in use, be sure they are differential probes which have no ground connection to the surged ground or to the equipment under test.

3.3.5 Safety Concerns During Surge Testing

Surge testing is hazardous. The equipment under test (EUT) can ignite, possibly explosively. Noxious, toxic and sometimes fatal fumes can be generated by the burning equipment. Accumulated gases may ignite explosively (i.e., flashover).

In an environment where surge testing takes place, it is absolutely crucial that these minimum safety precautions be taken:

- Surge testing should be performed only by properly trained test personnel who are experienced in conducting such tests, or be observed and supervised by such experienced personnel. No person subject to heart or neurological conditions should be allowed to conduct surge tests. Persons with pacemakers should not be allowed in or near the area where testing is conducted.
- Never leave a procedure or a test setup unattended.
- All personnel working in the area must be shielded with appropriate eye protection, body protection and electrical protection. They should not be allowed to work in a direct line of a possible explosion of the equipment under test.
- The test area should be a clear and unobstructed environment dedicated to such tests.
- The test area should be equipped with ventilating hoods and blowers to remove gases hat may be caused by exploding or burning components.
- The test area should have nonflammable walls and floors plus shielding to contain exploding parts and flames.
- There must be fire extinguishers certified for use in electrical and chemical fires readily available at the test site. DO NOT USE WATER TO EXTINGUISH AN ELECTRICAL FIRE.
- All flammable materials and debris must be outside the test area, and the area must be well marked, preferably by physical barriers, to prevent accidental intervention by non-test personnel while a test is in progress.

SECTION 3 - PRODUCT INFORMATION

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



3.4 Product Features



FIGURE 1 - Product Features – Front Panel

1	LCD Display
	Used in conjunction with control keypad to operate surge generator from the front panel.
2	Safety Interlock Port
-	This is a safety interlock port. Refer to section 4.2.1 for details.
3	Control Keypad
	For locally controlling the generator. Refer to section 6.4.1 for details.
4	EUT Power Switch
	This switch, in conjunction with the <i>TransWare-645™</i> EUT power enable function (when controlled remotely), is/are used to disable/enable EUT power at the front panel EUT power receptacle.
5	Internal CDN Surge Output Port - EUT Power Receptacle
	This is the EUT port of the internal coupling/decoupling network (CDN). Power line surges, as well as EUT input power are provided through this port.
6	Instrument Status LED Indicators
	These six LED indicators provide the present instrument status for the SGIEC-645.
7	System Power Switch
	This switch toggles ON/OFF the SGIEC-645 surge generator, when the system power input switch on the rear panel is in the ON position.
8	Fiber Optic Connector for Remote Interface
	The SGIEC-645 can be remotely controlled by a computer using Com-Power's TransWare- 645™ software, via this port. Refer to section 4.2.2 for details.
9	Sync Monitor Output Port
	The sync output port connects to the external trigger input of an oscilloscope.
10	Voltage Monitor Output Port
-	Connects to a high impedance oscilloscope input for verification of surge voltage level.
	SECTION 3 - PRODUCT INFORMATION

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



(11)

12

Current Monitor Output Port

Connects to a high impedance oscilloscope input for verification of surge current level.

Auxiliary (A/B) Surge Generator Output Port Terminals

These are the primary generator output terminals. Waveform calibration of the generator output is performed at these terminals (see section 5.4). These terminals are also used for connection to external Coupling/Decoupling Networks (CDNs) for telecommunication lines, data lines, single-phase power lines > 16A and three-phase power lines.

13 Front Panel Handles

These handles are typically used for rack-mount installation; for sliding the generator in and out of the rack.

14 Bottom-side Rubber Feet

For rack-mount installation, these feet may be removed by removing the two screws (per foot) which attach the feet to the chassis. The screws can then be removed from each foot and screwed back into their respective holes to re-secure the bottom cover.

15 Top-side Rubber Feet

For rack-mount installation, these feet may be removed by removing the two screws (per foot) which attach the feet to the chassis. The screws can then be removed from each foot and screwed back into their respective holes to re-secure the top cover.



FIGURE 2 - Product Features – Rear Panel

16 EUT Power Entry Switch

(17)

18

Toggles ON/OFF EUT power at input port, where the EUT power source enters the generator. **EUT Power Input Port**

This port connects to the EUT power source. See section 3.5 for input power specifications.

Grounding Bracket Connection Point

This is where the L-shaped grounding bracket connects to the chassis of the generator, using the supplied machine screws for attachment.

19 SGIEC-645 System Power Input Port

This port connects to the power source for the generator. See section 3.6 for input power specifications.

20 SGIEC-645 System Power Switch

This switch toggles ON/OFF the SGIEC-645 system input power. When this switch is in the ON position, the system may be turned on/off using the System Power Switch, located on the front panel \mathcal{O} .

SECTION 3 - PRODUCT INFORMATION

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



3.5 Product Specifications

Surge Output Waveform Parameters						
Surge Type (Source Impedance) @ Output Port	Open Circuit Voltage - V _{pk} (Volts)	Front Time - Tr (us)	Duration - T _d (us)	Short Circuit Current - I _{pk} (Amps)	Front Time - Tr (us)	Duration - T _d (us)
1.2/50 μs (2Ω) @ Generator Output	V _{set} ±10%	0.84-1.56	40-60	V _{set} / 2Ω ±10%	6.4-9.6	16-24
1.2/50 μs (2Ω) @ Internal CDN Output	V _{set} ±10%	0.84-1.56	40-60	V _{set} / 2Ω ±10%	6.4-9.6	16-24
1.2/50 μs (12Ω) @ Internal CDN Output	V _{set} ±10%	0.84-1.56	25-60	V _{set} / 12Ω ±10%	1.75-3.25	17.5-32.5
10/700 μs (40Ω) @ Generator Output	$V_{set}\pm 10\%$	7-13	560-840	V_{set} / $40\Omega \pm 10\%$	4-6	256-384
NOTE 1: Set Voltage (Vset) adjustable from 200-4000 Volts, in 1V increments NOTE 2: Voltage Overshoot/Undershoot for 1.2/50 µs Waveform (2Ω) @ Generator Output <-30% of Vset (in Volts)						
Monitor Ports		20.00	0 000. (1.			·)
Voltage Monito	ring Port (V _{mon}) 1000:	1 ±10% (V	(actual) = V(measur	_{ed)} * 1000)	
Current Monito	oring Port (Imon) 100:1	±10% (I=	= V(measured) * 100) [0.01 Vo	lts/Amp]
Sy	nc Output Por	† 0-5 V	DC			
Electrical						
E	Fuse Type UT Power Inpu	 5 Am 5 250 V 100 V 16 A 	DC (rms) (M AC (rms) (M DC (Maxin Mps up to	aximum) , 50/6 num) o 48 V _{DC} , 10 Am _i	0 Hz (16A ps up to 10	Max.) 00 Vdc
Input/Output C	onnectors					
EUT Po	ower Input Por		16B6 16A	IP44 Socket	nlet	
SGIEC-645 System EUT Pow	Power Input Por ver Output Por	t IEC C	13 Recep rsal Multi	or provided) otacle -Configuratio	n AC Soc	ket
Safet	y Interlock Por	t 4-pin	, 7mm Re	ceptacle		
F (A/B) Surg Monite	iber Optic Por 1e Output Port or Output Port	t Avag s (2) 4n s (3) BN	o Duplex nm bana IC-type (Latching POF na safety soc	jack kets	
Mechanical						
Dimensic) (4U) 7 t 53.5 l	7.75" x 19 bs (24.3 kg	" x 26.7 " (19.7 g)	x 48.3 x 67	7.7 cm)	
Environmental						
Operatin	g Temperature Cooling	e 40°F t g Force	o 104°F(d Air (inte	'5°C to 40°C) egral fan)		

SECTION 3 - PRODUCT INFORMATION

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917





FIGURE 3 - Product Dimensions

SECTION 3 - PRODUCT INFORMATION

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



4.0 Setting up the SGIEC-645

In the following sections, guidance is provided pertaining to the external electrical connections/interconnections of the SGIEC-645 System and accessories. The guidance is given on a port-by-port basis.

4.1 Input Power Line Ports

WARNING - DO NOT EXCEED THE RELEVANT INPUT POWER SPECIFICATIONS DETAILED IN SECTION 3.5 AND ON THE REAR PANEL OF THE GENERATOR ITSELF.

4.1.1 SGIEC-645 System Power Input Port



In accordance with international safety standards, this instrument is equipped with a three-wire power cable. When connected to an appropriate AC power outlet, this cable grounds the instrument frame.



For protection from electrical shock, the power cable ground must not be defeated.

The power plug must be plugged into an outlet that provides a protective earth ground connection.

4.1.1.1 System Power Input Port Fuse



To access fuse, insert the end of a small flatblade screwdriver into the slot as shown in Figure 4 to open the compartment.

Replace fuse only with same type and rating [250V, 5A (T)]. After replacing fuse, slide fuse holder firmly back into position within its cavity.

FIGURE 4 - Accessing the Input Power Fuse SECTION 4 - SETTING UP THE SGIEC-645

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



4.1.2 Equipment Under Test (EUT) Power Input Port



LOCKING MECHANISM

ONLY AFTER the SGIEC-645 is turned on, the power source which will power the Equipment Under Test (EUT) is to be connected to this input port through the provided, blue/gray/black AC power connector (wiring not included).

Illustrated in Figure 5 below are the instructions for the disassembly/assembly and wiring instructions for the connector.



FIGURE 5 - Wiring Procedure for EUT Power Input Plug

The EUT power may be AC or DC. DO NOT EXCEED THE RATINGS FOR THIS PORT DETAILED IN SECTION 3.5 AND/OR THE RATINGS DISPLAYED ON THE SGIEC-645 GENERATOR.

RE-TIGHTEN SCREWS

WARNING: TO AVOID POSSIBLE DAMAGE TO YOUR SGIEC-645 SURGE GENERATOR, DISCONNECT POWER FROM EUT POWER INPUT PORT WHEN POWERING ON OR OFF THE GENERATOR.

SECTION 4 - SETTING UP THE SGIEC-645

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917

BY ROTATING CLOCKWISE



4.1.2.1 Turning ON/OFF EUT Power – LOCAL Control

When the SGIEC-645 is NOT under software control, the EUT power state is controlled via the front and rear panel EUT POWER switches. If the EUT power input port is connected to an

active source, power is available at the EUT POWER OUTPUT port when both the rear panel and front panel switches are turned on. The EUT power status is also displayed at the top right of the front panel display on the Surge Setup Menu.



For any test or test sequence which includes surges applied to the internal CDN output terminals, the SGIEC-645 surge generator will automatically check the front panel EUT power switch status prior to the start of the test. If the EUT power switch is not enabled on the SGIEC-645 front panel, the following message will be displayed:



For any test or test sequence which includes phase synchronization of the surge waveform with the AC sine wave, the generator will check for its AC phase reference. If no phase reference is detected, the following message will be displayed.



In either case, if it is your intention to run the test without EUT power enabled, as would typically be the case during waveform verification, for instance; choose the CONTINUE option by pressing the button, and the test will begin. Phase synchronization will be automatically disabled.

Otherwise, choose the ABORT option by pressing the **1** button to abort the test.

SECTION 4 - SETTING UP THE SGIEC-645

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>



4.1.2.2 Turning ON/OFF EUT Power – REMOTE Control

When the SGIEC-645 is under remote control using the *TransWare-645™* software, the EUT power state is controlled via the front and rear panel EUT POWER switches, in addition to the EUT POWER function located on the Control Panel within the TransWare-645™ software.

Se Tra	insWare-645	Liste							
			Coupling	Immeriance Wiltons #Toote	Output Terminale	Polarity	Phace Reference	annia (*) Interval (sec.) Enable	Ctatue
			,	Enter Tas (Edit Se	sks To Con quence > A	tinue \dd)			
		EDIT SEC	OVENCE OPTIONS		SEQUENCE WIZARD		OFF EUT POWER	CONTROLS	
								Communication : DISCONNECTED	LOCAL

When the SGIEC-645 front panel EUT POWER switch is turned on, the EUT power status in the TransWare-645[™] Control Panel will change from "**OFF**" to "**RDY**". At this point, the EUT power output can be turned on by pressing the *TransWare-645[™]* EUT POWER button.

The SGIEC-645 surge generator will automatically check the EUT power switch status at the start of any test or test sequence which includes surges applied to its internal CDN output terminals. If the EUT power switch is not enabled on the SGIEC-645 front panel, the following message will be displayed:



For any test or test sequence which includes phase synchronization of the surge waveform with the AC sine wave, the generator will check for its AC phase reference. If no phase reference is detected, the following message will be displayed:



In either case, if it is your intention to run the test without EUT power enabled, as would typically be the case during waveform verification, for instance; press the CONTINUE button, and the test will begin. Phase synchronization will be automatically disabled for the test/test sequence.

Otherwise, abort the test by pressing the ABORT button.

SECTION 4 - SETTING UP THE SGIEC-645

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917



4.2 Input/Output Ports

4.2.1 Safety Interlock Port



The safety interlock port (*left*) can (optionally) be used to disable the surge generator output for safety reasons or otherwise using an external SPST switch, such as the door contacts of the test chamber, for instance. In cases where no interlock switch is used, simply connect the safety interlock key (*right*) to this port to enable the generator.



For those cases where an external switch is to be used, wire your switch contacts to pins 2 and 3 of the supplied, spare 7mm push-pull connector as shown in Figure 6. Remove the interlock key from the SGIEC-645 interlock port, and plug in the wired switch assembly. The generator will now be enabled/disabled with the closing/opening of the switch contacts.



FIGURE 6 - Safety Interlock Connector Pin-Out & Ext. Switch Connection

SECTION 4 - SETTING UP THE SGIEC-645

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



4.2.2 Fiber Optic Port

The SGIEC-645 surge generator can be remotely controlled using a PC via the fiber optic remote interface, using Com-Power's *TransWare-645TM* software.

4.2.2.1 Setting up the Remote Interface



As shown in Figure 7, connect the supplied fiber optic cable into the fiber optic remote interface port on the front of the SGIEC-645. Connect the opposite end of the fiber optic cable to the OTA-232 Optical Transreceiver Adapter. Finally, connect the OTA-232

Adapter to a PC with the Com-Power TransWare-645[™] software installed using the supplied USB Type A to USB Type B cable.



FIGURE 7 - Remote Interface Setup Example

Once connection has been made between the computer and the SGIEC-645, the message to the right will appear on the front panel display of the generator.



If the *TransWare-645™* software is closed, or the fiber optic or USB cable is disconnected, causing a break in the link, the message below will be will appear on the front panel display of



the generator.

Refer to section 7 for detailed instructions on operation of the SGIEC-645 Surge Generator via the *TransWare-645*™ software.

SECTION 4 - SETTING UP THE SGIEC-645

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>



4.3 Monitor Ports



The Vmon & Imon monitor ports provide a convenient method for verification of the voltage/current levels of the applied surges.

The Sync. Output Port provides a convenient method for triggering the oscilloscope during the measurements made at the voltage or current

monitor ports, as well as for measurements at the Auxiliary Surge Outputs, Internal CDN Surge Output Ports, and Surge Output Ports of any external CDN (for data lines, telecom lines or power lines).

4.3.1 Sync Output Port (Sync. O/P)

The SYNC OUTPUT port is provided as an alternative method of triggering the oscilloscope measurement, rather triggering on the rising or falling slope of the surge waveform. The SYNC OUTPUT port connects directly to the external trigger input of any oscilloscope. The output is 5 VDC steady state, until it

drops to zero volts in synchronization with each surge discharge, for a period of 20 ms.

4.3.2 Voltage Monitor Port (V_{mon})

The Voltage Monitor Port (Vmon) is intended to be connected to a high impedance (> $10k\Omega$) input of an oscilloscope for verification of peak surge voltage for all waveforms. The output scaling is 1V / 1000V (1000:1 ratio).

The peak output voltage measured at this port is typically accurate to within $\pm 10\%$.

The actual wave shape of the surge waveform may become distorted; and therefore this port should not be used for measurement of other parameters, such as rise time, decay time or over/undershoot. These parameters must be measured at the respective surge output terminals.

4.3.3 Current Monitor Port (I_{mon})

The Current Monitor Port (Imon) is intended to be connected to a high impedance (>10k Ω) input of an oscilloscope for verification of peak surge current for all waveforms. The output scaling is 1V / 100V (100:1 ratio).

The peak output current measured at this port is typically accurate to within $\pm 10\%$.

* **Open circuit** voltage measurements are performed with no external connections to the selected surge output terminals. **Short circuit** current measurements are performed with the surge output terminals short circuited. Measured values will vary with alternate output terminations (with the EUT connected, for instance).

SECTION 4 - SETTING UP THE SGIEC-645

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



4.4 Surge Generator Output Ports



The (A/B) output ports are fitted with 4 mm safety sockets.

The internal power line CDN output port is fitted with a Universal Multi-Configuration AC Socket.



CAUTION: Due to the presence of **DANGEROUS VOLTAGES**, the user should avoid all contact with these output ports, as well as any uninsulated cabling which connects to these ports while the SGIEC-645 is in operation. All connections should be made before applying power to the generator.



WARNING: Uninsulated, **DANGEROUS VOLTAGES** may be present on any and all surge output terminals. These voltages may be of sufficient magnitude to constitute a risk of electric shock to persons.

WARNING

NEVER CONNECT THE SURGE OUTPUT TERMINALS TO A POWER SOURCE DIRECTLY, AS THIS MAY RESULT IN INTERNAL DAMAGE TO YOUR SGIEC-645 SURGE GENERATOR. THESE ARE OUTPUT PORTS ONLY.

SECTION 4 - SETTING UP THE SGIEC-645

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917



4.4.1 Auxiliary (A/B) Surge Output Ports



FIGURE 8 - Connection to External CDN via Auxiliary (A/B) Ports

4.4.2 Internal Powerline CDN Surge Output Port



Powerline surges will always be applied through a coupling/decoupling network (CDN). The SGIEC-645 surge generator includes an internal CDN accommodating both DC (16A up to 48V/10A up to 100V) and single-phase AC powered devices up to 16 amps.

For devices drawing greater than 16 amps of current

and/or devices requiring a 3-phase power system, a compatible Com-Power external CDN is required, which connects to the (A/B) output terminals of the generator.

The powerline surges are typically applied between two current carrying conductors (Line to Line - differential mode) and between any current carrying conductor and ground (Line to Ground – common mode) A typical test setup is illustrated in Figure 9



FIGURE 9 - EUT Connection to SGIEC-645 for Powerline Surge(s)

SECTION 4 - SETTING UP THE SGIEC-645

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



5.0 Calibration of Surge Output Waveforms

This section provides guidance on the measurement (and associated calculations) of the SGIEC-645 Surge Generator output waveforms at the auxiliary(A/B) output terminals and at the EUT power output port terminals.

5.1 Recommended Test Equipment

Listed below are the three key components recommended for surge waveform measurements.

- 1) Digital Storage Oscilloscope ($BW \ge 100 \text{ MHz}$)
- 2) High Voltage (1000x1) Differential Oscilloscope Probe Set (BW \geq 10 MHz)
- 3) Current Probe (BW \geq 10 MHz, LF cutoff \leq 0.5 Hz)
- 4) Coaxial cables, adapters and/or fixtures as necessary so that all required connections can be made properly.

5.2 Surge Waveform Measurements

As discussed in the following sections, open circuit voltage measurements are to be performed using high-voltage, **differential-type** oscilloscope probes, while the short circuit current measurements are made using an appropriate current probe.

5.2.1 Open Circuit Voltage Measurements

Open circuit voltage waveform measurements are made using highvoltage, differential-type oscilloscope probes connected directly to the appropriate SGIEC-645 output terminals.

5.2.2 Short Circuit Current Measurements

Short circuit current waveform measurements are made by shorting the appropriate output terminals using a short length of wire routed through an appropriate current probe, which is connected to the input of the oscilloscope.

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



5.3 Measurement Connections

Examples of typical measurement connection arrangements at the Auxiliary (A/B) surge output ports of the SGIEC-645 for both <u>open circuit voltage</u> (left) and <u>short</u> <u>circuit current</u> (right) are shown below in Figure 10.



FIGURE 10 - Example of Probe Connections at Auxiliary Output Port



FIGURE 11 - Example of Probe Connections at Internal CDN Output Port



5.4 Surge Waveform Requirements (Generator Output)

IMPORTANT: The surge waveform requirements defined within this section apply only to surges measured at the [Auxiliary (A/B)] Generator Output terminals. Modified and/or relaxed waveform requirements have been defined for surges measured at the EUT port of coupling/decoupling networks. These requirements are detailed in Section 5.5 and 5.6 of this manual.

The waveform requirements for surges measured at the [Auxiliary (A/B] Generator Output Terminals are defined in terms of both open circuit voltage and short circuit current waveform requirements. For both voltage and current waveforms, the following parameters are defined:

OPEN CIRCUIT VOLTAGE WAVEFORM	SHORT CIRCUIT CURRENT WAVEFORM
Peak Voltage (V _{pk})	Peak Current (Ipk)
Under/Overshoot (V _{u/o})	Under/Overshoot (l _{u/o})
Front Time (T _f)	Front Time (T _f)
Duration (Id)	Duration (T _d)

TABLE I – Defined Waveform Parameters - Generator Output

Given in Table I (below) are the defined limits/limit ranges for the individual waveform parameters for each surge type, as measured at the [Auxiliary (A/B)] Generator Output Terminals.

TABLE II – Waveform Requirements – Generator Output

	Waveform Parameter	1.2/50 μs (OC), 8/20 μs (SC) Combination Wave	10/700 μs (OC), 5/320 μs (SC) Combination Wave	
.±	Peak Voltage (V _{pk})	Set Voltage ±10%	Set Voltage ±10%	
Open Circui	Under/Overshoot (V _{u/o})	Set Voltage * -0.3	N/A	
	Front Time (T _f)	0.84-1.56 µs	7-13 µs	
	Duration (T _d)	40-60 µs	560-840 µs	
+	Peak Current (I _{pk})	(Set Voltage / 2 Ω) ±10%	(Set Voltage / 40 Ω) ±10%	
hort Circui	Under/Overshoot (l _{u/o})	(Set Voltage / 2Ω) * -0.3	N/A	
	Front Time (T _f)	6.4-9.6 µs	4-6 µs	
S	Duration (T _d)	16-24 µs	256-384 µs	

These waveform requirements are discussed in more detail in the following sections. Measurement guidelines, as well as guidelines and examples of the associated calculations are also provided.

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



5.4.1 Open Circuit Surge Voltage Waveforms – Generator Output

The waveform in Figures 12 and 13 define the open circuit voltage wave shapes at the generator output for the two respective combination waveforms.



FIGURE 12 - 1.2/50 µs, 8/20 µs - Open Circuit Voltage Wave Shape



FIGURE 13 - 10/700 µs, 5/320 µs - Open Circuit Voltage Wave Shape





5.4.1.1 Measurement of Voltage Waveform Parameters

This section discusses the measurement process and calculations for proper determination of the individual waveform parameter values for surges measured at the [Auxiliary (A/B)] Generator Output Terminals.

PEAK VOLTAGE (V_{pk})

For positive surges, the Peak Voltage (V_{pk}) is the highest measured voltage value within the envelope of the surge waveform. For negative surges, the Peak Voltage (V_{pk}) is the lowest measured voltage value within the envelope of the surge waveform.

UNDER/OVERSHOOT VOLTAGE (Vu/o)

For positive surges, the Undershoot Voltage (V_u) is the lowest measured voltage value within the envelope of the surge waveform. For negative surges, the Overshoot Voltage (V_o) is the highest measured voltage value within the envelope of the surge waveform.

FRONT TIME (T_f)

The Front Time (Tf) is calculated based on the measurement of **T**, which is defined below:

T = Time difference between:

- (A) the first point on the rising slope of the waveform at or above 30% of V_{pk}; and,
- (B) the first point on the rising slope of the waveform at or above 90% of V_{pk} .

$\mathbf{T}_{\mathbf{r}} = 1.67 \times \mathbf{T}$

DURATION (T_d)

The **Duration** (T_d) [also known as fall or decay time] is calculated based on the measurement of T_w .

$\mathbf{T}_{\mathbf{w}}$ = Time difference between:

- (A) the first point on the rising slope of the waveform at or above 50% of $V_{\text{pk}};$ and,
- (B) the first point on the falling slope of the waveform at or below 50% of V_{pk}.

 $T_d = T_w$

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



5.4.1.2 Example calculations for Voltage Waveform Parameters

Considered in the following example calculations is a typical 1.2/50 μ s, 8/20 μ s Combination Wave Surge, with V_{pk} setting of 1 kV applied to the Auxiliary (A/B) surge output ports with a source impedance of 2 ohms.

NOTE: The final values determined for each waveform parameter are shown in blue (with the respective limit range in red)

The following values were measured:

MEASURED VALUES

V _{pk} :	1,004.64 Volts	(Limit Range: 900-1100V)
Vus:	0 Volts	(Limit [min.]: -300V)
V(30%/pk):	301.392 Volts	T(30%/pk): 0.723 μs
V(90%/pk):	904.176 Volts	T(90%/pk): 1.423 μs
V(50%-Rise/pk):	502.32 Volts	T(50%/pk): 0.859 μs
V(50%-Fall/pk):	502.32 Volts	T(50%/pk): 55.95 µs

Based on these measured values, the following parameters are calculated:

FRONT TIME (Tf) = T x 1.67

- $T = T_{(90\%/pk)} T_{(30\%/pk)}$
- $T = 1.423 \,\mu s 0.723 \,\mu s$
- T = 0.7 μs

 $T_r = 1.169 \, \mu s$

 $T_r = 0.7 \ \mu s \ x \ 1.67$

(Limit Range: 0.84-1.56 µs)

DURATION (Td) = Tw = T(50%-Fall/pk) - T(50%-Rise/pk)

- $T_w = 55.95 \,\mu s 0.859 \,\mu s$
- $T_w = 55.09 \, \mu s$
- T_d = 55.09 μs (Limit Range: 40-60 μs)

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



5.4.2 Short Circuit Surge Current Waveforms

The waveforms in Figures 14 and 15 define the short circuit current wave shape requirements at the generator output for the two respective combination waveforms.



FIGURE 14 - 1.2/50 µs, 8/20 µs - Short Circuit Current Wave Shape



FIGURE 15 - 10/700 µs, 5/320 µs - Short Circuit Current Wave Shape





5.4.2.1 Measurement of Current Waveform Parameters

This section discusses the measurement process and calculations for proper determination of the individual waveform parameter values.

PEAK CURRENT (Ipk)

For positive surges, the Peak Current (I_{pk}) is the highest measured current value within the envelope of the surge waveform. For negative surges, the Peak Current (I_{pk}) is the lowest measured current value within the envelope of the surge waveform.

UNDER/OVERSHOOT CURRENT (Iu/o)

For positive surges, the Undershoot Current (I_{υ}) is the lowest measured current value within the envelope of the surge waveform. For negative surges, the Overshoot Current (I_{υ}) is the highest measured current value within the envelope of the surge waveform.

FRONT TIME (Tf)

The Front Time (T_f) is calculated based on the measurement of T, which is defined below:

T = Time difference between:

- (A) the first point on the rising slope of the waveform at or above 10% of Ipk; and,
- (B) the first point on the rising slope of the waveform at or above 90% of I_{pk}.

$T_r = 1.25 \times T$

DURATION (T_d)

The **Duration** (T_d) [also known as fall or decay time] is calculated based on the measurement of T_w .

 T_w = Time difference between:

- (A) the first point on the rising slope of the waveform at or above 50% of $V_{\text{pk}};$ and,
- (B) the first point on the falling slope of the waveform at or below **50%** of V_{pk}.

 $T_d = 1.18 \times T_w$

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



Example calculations for Current Waveform Parameters 5.4.2.2

Considered in the following example calculations is a typical 1.2/50 $\mu s,$ 8/20 μs Combination Wave Surge, with V_{pk} setting of 1 kV, applied at the Auxiliary (A/B) Surge Output Ports, with a 2 ohm source impedance.

NOTE: The final values determined for each waveform parameter are shown in blue (with the respective limit range in red)

The following values were measured:

MEASURED VALUES

lpk:	488 Amps	(Limit Range:	450-550A)
lu:	-120 Amps	(Limit [min.]: •	-150A)
l(10%/pk):	48.8 Amps	T(10%/pk):	-2.912 µs
l(90%/pk):	439.2 Amps	T(90%/pk):	2.916 µs
l(50%-Rise/pk):	244 Amps	T(50%/pk):	-0.78 µs
l(50%-Fall/pk):	244 Amps	T(50%/pk):	15.24 µs

Based on these measured values, the following parameters are calculated:

FRONT TIME (Tf) = T x 1.25

$$T = T(90\%/pk) - T(30\%/pk)$$

T =
$$2.916 \,\mu s - -2.912 \,\mu s$$

T = $5.828 \,\mu s$

$$T_r = 5.828 \,\mu s \times 1.25$$

nit Range: 6.4-9.6 µs)

DURATION (Td) = $1.18 \times T_w = T_{(50\%-Fall/pk)} - T_{(50\%-Rise/pk)}$

$$T_w = 16.02 \, \mu s$$

$$T_d = 16.02 \,\mu s \times 1.18$$

(Limit Range: 16-24 µs)

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



5.5 Surge Waveform Requirements at CDN Outputs

IMPORTANT: The surge waveform requirements defined within this section apply only to surges measured at the EUT port of Coupling/Decoupling Networks (CDN). For waveform requirements for surges measured at the [Auxiliary (A/B)] Generator Output terminals, refer to Section 5.4.

5.5.1 CDN for Power Lines -1.2/50 µs, 8/20 µs Waveform

The waveform requirements for surges measured at the EUT port of power line coupling/decoupling networks (CDN) for the 1.2/50 µs, 8/20 µs Combination Wave Surge are given in Tables III through VI.

The waveforms are defined in terms of both:

open circuit voltage; and, short circuit current

For both voltage and current waveforms, parameters are defined for generator source impedances of:

2 ohms (18 μF coupling capacitor [line to line surges]); and, 12 ohms (9 μF coupling capacitor [line to ground surges])

TABLE III – Defined Waveform Parameters – EUT Port of CDN

OPEN CIRCUIT	SHORT CIRCUIT
VOLTAGE WAVEFORM	CURRENT WAVEFORM
Peak Voltage (V _{pk})	Peak Current (I _{pk})
Front Time (T _f)	Front Time (T _f)
Duration (T _d)	Duration (T _d)
Phase Synchronization	N/A

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917

Surge voltage parameters under open-circuit conditions		Coupling Impedance			
		2Ω (18 μF) (line to line)	12Ω (9 μF) (line to ground)		
Ð	Current Rating ≤ 16A	Set Voltage +10% / -10%	Set Voltage +10% / -10%		
Peak Voltag (V _{pk})	16A < Current Rating ≥ 32A	Set Voltage +10% / -10%	Set Voltage +10% / -10%		
	32A < Current Rating ≥ 63A	Set Voltage +10% / -10%	Set Voltage +10% / -15%		
	63A < Current Rating ≥ 125A	Set Voltage +10% / -10%	Set Voltage +10% / -20%		
	125A < Current Rating ≥ 200A	Set Voltage +10% / -10%	Set Voltage +10% / -25%		
Front Time (Tf)		1.2 µs ±30%	1.2 µs ±30%		
_	Current Rating ≤ 16A	50 µs +10 µs / -10 µs	50 µs +10 µs / -25 µs		
uration (Ta	16A < Current Rating ≥ 32A	50 µs +10 µs / -15 µs	50 µs +10 µs / -30 µs		
	32A < Current Rating ≥ 63A	50 µs +10 µs / -20 µs	50 µs +10 µs / -35 µs		
	$63A < Current Rating \ge 125A$	50 µs +10 µs / -25 µs	50 µs +10 µs / -40 µs		
	125A < Current Rating ≥ 200A	50 µs +10 µs / -30 µs	50 µs +10 µs / -45 µs		

TABLE IV – Voltage Waveform Limits – EUT Port of Power Line CDN

TABLE V – Current Waveform Limits – EUT Port of Power Line CDN

Surge current	Coupling Impedance			
parameters under short-circuit conditions	2Ω (18 μF) (line to line)	12Ω (9 μF) (line to ground)		
Front Time (Tf)	Tf = 1.25 x Tr = 8 μs ±20%	Tf = 1.25 x Tr = 2.5 µs ±30%		
Duration (Td)	Td = 1.18 x Tw = 20 µs ±20%	T_d = 1.04 x T_w = 25 µs ±30%		

TABLE VI – Peak Voltage/Current Relationship – Power Line CDN

Open-circuit peak voltage ±10% at EUT port of the CDN	Short-circuit peak current ±10% at EUT port of the CDN 2Ω (18 μF) (line to line)	Short-circuit peak current ±10% at EUT port of the CDN 12Ω (9 μF) (line to ground)		
0.5 kV	0.25 kA	41.7 A		
1.0 kV	0.5 kA	83.3 A		
2.0 kV	1.0 kA	166.7 A		
4.0 kV	2.0 kA	333.3 A		

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



5.5.2 CDN for Data Lines - 1.2/50 µs, 8/20 µs Waveform

A summary of the calibration process and waveform requirements for surges measured at the EUT port of a CDN for unsymmetrical interconnection (data) lines for the $1.2/50 \ \mu$ s, $8/20 \ \mu$ s Combination Wave Surge are given in Tables VII and VIII, respectively.

The waveforms are defined in terms of both:

open circuit voltage; and, short circuit current

For both voltage and current waveforms, parameters are defined for the following surge coupling devices:

0.5 µF Coupling Capacitor; and, Gas Discharge Tube (GDT)

TABLE VII – Calibration Process Summary – Data Line CDN

	Coupling	Measuring	AE Side	EUT Side	
Surge voltage at EUT side	Single line to PE	Single line, V _{pk} , T _f , T _d	All lines shorted to PE	Open-circuit	
Surge current at EUT side	Single line to PE	Single line, V _{pk} , T _f , T _d	All lines shorted to PE	Short-circuit	
Surge voltage at EUT side	Single line to line	Single line, V _{pk} , T _f , T _d	All lines shorted to PE	Open-circuit	
Surge current at EUT side	Single line to line	Single line, V _{pk} , T _f , T _d	All lines shorted to PE	Short-circuit	
Residual voltage on AE side (with protection elements)	Single line to PE	Line to PE at a time V _{pk}	Open-circuit	Open-circuit	

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917

Coupling Method	Output Voltage Setting	Voc @ CDN EUT Port ±10%	Voltage Front Time (Tf) Tf=1.67 x Tr ±30%	Voltage Duration (Ta) Ta = Tw ±30%	lsc @ CDN EUT Port ±20%	Current Front Time (Tf) Tf=1.25 x Tr ±30%	Current Duration (Td) Td=1.18 x Tw ±30%
Line to PE R = 40Ω CD = 0.5 μF	4 kV	4 kV	1.2 µs	38 µs	87 A	1.3 µs	13 µs
Line to PE R = 40Ω CD = GDT	4 kV	4 kV	1.2 µs	42 µs	95 A	1.5 µs	48 µs
Line to Line R = 40Ω CD = 0.5 μF	4 kV	4 kV	1.2 µs	42 µs	87 A	1.3 µs	13 µs
Line to Line R = 40Ω CD = GDT	4 kV	4 kV	1.2 µs	47 µs	95 A	1.5 µs	48 µs

TABLE VIII – Surge Waveform Specifications – Data Line CDN

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917


5.5.3 CDN for Telecom Lines - 1.2/50 µs, 8/20 µs Waveform

A summary of the calibration process and waveform requirements for surges measured at the EUT port of a CDN for symmetrical interconnection (telecom) lines for the 1.2/50 μ s, 8/20 μ s Combination Wave Surge are given in Tables IX and X, respectively.

The waveforms are defined in terms of both:

open circuit voltage; and, short circuit current

	Coupling	Measuring	AE Side	EUT Side
Surge voltage at EUT side	Common mode – all lines to PE 40Ω path	All lines shorted together V _{pk} , Tf, Td	All lines shorted to PE	Open-circuit all lines connected together
Surge current at EUT side	Common mode – all lines to PE 40 Ω path	All lines shorted together V _{pk} , Tf, Td	All lines shorted to PE	All lines shorted to PE
Residual voltage on AE side (with protection elements)	Common mode – all lines to PE 40Ω path	Each line to PE in turn V _{pk}	Open- circuit	Open-circuit

TABLE IX – Calibration Process Summary – Telecom Line CDN (1.2/50)

TABLE X – Surge Waveform Specifications – Telecom Line CDN (1.2/50)

Coupling Method	Output Voltage Setting	V _{oc} @ CDN EUT Port ±10%	Voltage Front Time (Tf) Tf=1.67 x Tr ±30%	Voltage Duration (Td) Td = Tw ±30%	lsc @ CDN EUT Port ±20%	Current Front Time (Tf) Tf=1.25 x Tr ±30%	Current Duration (Td) Td=1.18 x Tw ±30%
Common mode CD 40Ω path	2 kV	2 kV	1.2 µs	45 µs	48 A	1.5 µs	45 µs

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



5.5.4 CDN for Telecom Lines – 10/700 µs, 5/320 µs Waveform

A summary of the calibration process and waveform requirements for surges measured at the EUT port of a CDN for symmetrical interconnection (telecom) lines for the 10/700 μ s, 5/320 μ s Combination Wave Surge are given in Tables XI and XII, respectively.

The waveforms are defined in terms of both:

open circuit voltage; and, short circuit current

	Coupling	Measuring	AE Side	EUT Side
Surge voltage at EUT side	Common mode – one pair to PE	Both lines from one pair shorted together V _{pk} , T _f , T _d	All used lines shorted to PE	Open- circuit, both lines from one pair shorted together
Surge current at EUT side	Common mode – one pair to PE	Both lines from one pair shorted together V _{pk} , T _f , T _d	All used lines shorted to PE	Both lines from one pair shorted to PE
Residual voltage on AE side (with protection elements)	Common mode – one pair to PE	Both lines from one pair shorted together V _{pk}	Open-circuit	Open-circuit

TABLE XI – Calibration Process Summary – Telecom Line CDN (10/700)

TABLE XII – Surge Waveform Specifications – Telecom Line CDN (10/700)

Coupling Method	Output Voltage Setting	Voc @ CDN EUT Port ±10%	Voltage Front Time (Tf) Tf=1.67 x Tr ±30%	Voltage Duration (Td) Td = Tw ±30%	lsc @ CDN EUT Port ±20%	Current Front Time (Tf) Tf=1.25 x Tr ±30%	Current Duration (Td) Td=1.18 x Tw ±30%
Common mode CD 1 Pair 27.5Ω	4 kV	4 kV	8 µs	250 µs	145 A	3.2 µs	250 µs

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



5.6 Combined Reference Table of Waveform Limits

Combined in the following table are all of the surge output waveform requirements for both Combination Waves, at each of the respective surge generator/CDN outputs.

TABLE XIII – Combined Reference Table of IEC 61000-4-5 Waveform Limit Tables

	Surge Waveform:	1.2/50 µs, 8/20 µs COMBINATION WAVE					10/700 μ COMBINA	s, 5/320 µs TION WAVE	
	Generator Source Impedance:	2 (18 µF cou	Ω upling cap)	2 Ω +109 (9 μF cou	Ω = 12Ω pling cap)	2Ω+40	Ω = 42Ω	40Ω @ Gen 15Ω+(25Ω @ CDI	erator Output 25Ω)= 27.5Ω N Output
	SURGE GENERATOR OUTPUT TERMINALS	OPEN (voltage)	SHORT (current)	OPEN (voltage)	SHORT (current)	OPEN (voltage)	SHORT (current)	OPEN (voltage)	SHORT (current)
	Generator Output [Aux. (A/B)]	V _{set} ±10%	V _{set(V)} /2Ω=(A) ±10%					V _{set} ±10%	V _{set} /40Ω=(A) ±10%
int	Power Line CDN ≤ 16A	V _{set} ±10%	V _{set(V)} /2Ω=(A) ±10%	V _{set} ±10%	V _{set(V)} /12Ω=(A) +10%/-10%				
urre	Power Line CDN > 16A ≤ 32A	V _{set} ±10%	V _{set(V)} /2Ω=(A) ±10%	V _{set} ±10%	V _{set(V)} /12Ω=(A) +10%/-10%				
)/€	Power Line CDN > 32A ≤ 63A	V _{set} ±10%	V _{set(V)} /2Ω=(A) ±10%	V _{set} ±10%	V _{set(V)} /12Ω=(A) +10%/-15%				
ag€	Power Line CDN > 63A ≤ 125A	V _{set} ±10%	V _{set(V)} /2Ω=(A) ±10%	V _{set} ±10%	V _{set(V)} /12Ω=(A) +10%/-20%				
Volt	Power Line CDN > 125A ≤ 200A	V _{set} ±10%	V _{set(V)} /2Ω=(A) ±10%	V _{set} ±10%	V _{set(V)} /12Ω=(A) +10%/-25%				
ak \	Telecom Line CDN					V _{set} ±10%	V _{set(V)} /42Ω=(A) ±20%	V _{set} ±10%	V _{set(V)} /27.5Ω=(A) ±20%
Ре	Data Line CDN (0.5 µF CD)					V _{set} ±10%	V _{set(V)} /46Ω=(A) ±20%		
	Data Line CDN (GDT CD)					V _{set} ±10%	V _{set(V)} /42Ω=(A) ±20%		
	Under/Overshoot Voltage/Current Generator Output	-30%[V _{set}]	-30% [V _{set(V)} /2Ω=(A)]						
	Generator Output	$T_f = 1.67 \times T$	$T_f = 1.25 \times T_r$ = 8 us +20%					$T_f = 1.67 \times T_r$ = 10 us ±30%	$T_f = 1.25 \times T_r$ = 5 us +20%
(Power Line CDN < 200A	$T_f = 1.67 \times T_r$ = 1.2 µs ±30%	$T_f = 1.25 \times T_r$ = 8 µs +20%	$T_f = 1.67 \times T_r$ = 1.2 µs +30%	$T_f = 1.25 \times T_r$ = 2.5 µs +30%			10 µ3 =00/0	0 µ3 =20/0
∋ (T _f	Telecom Line CDN	112 ps =0070	0 µ3 =20/0	1.2 µ3 =00/0	2.0 µ3 =0070	$T_f = 1.67 \times T_r$ = 1.2 us +30%	$T_f = 1.25 \times T_r$ = 1.5 us +30%	$T_f = 1.67 \times T_r$ = 8 µs +30%	$T_f = 1.25 \times T_r$ = 3.2 µs +30%
lim€	Data Line CDN (0.5 µF CD, L-PE)					$T_f = 1.67 \times T_r$ = 1.2 µs ±30%	$T_f = 1.25 \times T_r$ = 1.3 µs ±30%		
nt 1	Data Line CDN (GDT CD, L-PE)					$T_f = 1.67 \times T_r$ = 1.2 µs ±30%	T _f = 1.25 x T _r = 1.5 µs ±30%		
Frc	Data Line CDN (0.5 µF CD, L-L)					$T_f = 1.67 \times T_r$ = 1.2 µs ±30%	T _f = 1.25 x T _r = 1.3 µs ±30%		
	Data Line CDN (GDT CD, L-L)					$T_f = 1.67 \times T_r$ = 1.2 µs ±30%	$T_f = 1.25 \times T_r$ = 1.5 µs ±30%		
	Generator Output	$T_{d} = T_{w}$ = 50 µs ±20%	T _d = 1.18 x T _w = 20 µs ±20%					T _d = T _w = 700 μs ±20%	T _d = T _w = 320 µs ±20%
	Power Line CDN ≤ 16A	T _d = T _w = 50 μs +10 μs/-10 μs	T _d = 1.18 x T _w = 20 μs ±20%	T _d = T _w = 50 μs +10 μs/-25 μs	T _d = 1.04 x T _w = 25 μs ±30%				
	Power Line CDN > 16A ≤ 32A	T _d = T _w = 50 μs +10 μs/-15 μs	T _d = 1.18 x T _w = 20 μs ±20%	T _d = T _w = 50 μs +10 μs/-30 μs	T _d = 1.04 x T _w = 25 μs ±30%				
(Power Line CDN > 32A ≤ 63A	T _d = T _w = 50 μs +10 μs/-20 μs	T _d = 1.18 x T _w = 20 μs ±20%	T _d = T _w = 50 μs +10 μs/-35 μs	T _d = 1.04 x T _w = 25 μs ±30%				
(T_{d})	Power Line CDN > 63A ≤ 125A	T _d = T _w = 50 μs +10 μs/-25 μs	T _d = 1.18 x T _w = 20 μs ±20%	T _d = T _w = 50 μs +10 μs/-40 μs	T _d = 1.04 x T _w = 25 μs ±30%				
tion	Power Line CDN > 125A ≤ 200A	T _d = T _w = 50 μs +10 μs/-30 μs	T _d = 1.18 x T _w = 20 μs ±20%	T _d = T _w = 50 μs +10 μs/-50 μs	T _d = 1.04 x T _w = 25 µs ±30%				
urai	Telecom Line CDN					T _d = T _w = 45 μs ±30%	T _d = 1.18 x T _w = 45 µs ±30%	T _d = T _w = 250 μs ±30%	T _d = T _w = 250 μs ±30%
D	Data Line CDN (0.5 µF CD, L-PE)					T _d = T _w = 38 μs ±30%	T _d = 1.18 x T _w = 13 µs ±30%		
	Data Line CDN (GDT CD, L-PE)					T _d = T _w = 42 μs ±30%	T _d = 1.18 x T _w = 48 μs ±30%		
	Data Line CDN (0.5 µF CD, L-L)					T _d = T _w = 42 μs ±30%	T _d = 1.18 x T _w = 13 μs ±30%		
	Data Line CDN (GDT CD, L-L)					T _d = T _w = 47 μs ±30%	T _d = 1.18 x T _w = 48 µs ±30%		

SECTION 5 - CALIBRATION OF SURGE OUTPUT WAVEFORMS

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



6.0 Controlling the SGIEC-645 via its Front Panel

The SGIEC-645 Surge Generator is able to perform all of its individual functions from the front panel interface, as described in the following sections. For either combination surge wave, the user can define the peak voltage level, surge output port, coupling mode, number of surges, delay time between surges, source impedance and AC sine wave synchronization angle (when applicable).

Further functionality, such as programming surge sequences and creating active test logs for recording results and observations during tests, is available using Com-Power's *TransWare-645™* PC software, which controls the SGIEC-645 remotely via its fiber optic interface and fiber optic to USB adapter. Refer to section 7 for instructions on controlling the SGIEC-645 Surge Generator using *TransWare-645™*.

6.1 Initial Startup

To turn on the generator, locate the **NEMA 5-15R-male to IEC C13-female** power cord supplied with the generator. Plug the IEC C13 plug end of the cord into the system power input port on the back of the generator. Plug the other end of the power cord into an appropriate power outlet.

Turn on the system power switch located on the rear panel. Then, press the SYSTEM POWER button on the lower left corner of the front panel. The SGIEC-645 Surge Generator should then power up.

After power-up, the following splash screens will appear succe	essively.
--	-----------

SURGE WAVEFORM	SURGE SOURCE	EUT E POWER	SURGE WAVEFORM		JRGE JPLING	SOURCE	EUT POWER
C O M – P S G (S U R G E	0 W E R C O R I E C - 6 4 5 G E N E R A T O	P. (JNIT SOFTW	SR. ARE	NO. VER	:90(.:1.() 0 0 2)
GENERATOR	SURGE COUNT	TIME TILL NEXT SURGE	GENERATOI STATUS) R	SURGE COUNT		TIME TILL EXT SURGE

No user action is required at this point.

SECTION 6 - CONTROLLING THE SGIEC-645 VIA ITS FRONT PANEL

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



6.2 Self-Test

Each time the SGIEC-645 is turned on, it will automatically perform a three-stage self-test, and the following message will be displayed:



During the self-test, the following operations occur automatically:

- 1) SWITCHING RELAYS ON/OFF During first stage of Self-Test, relays will toggle ON and OFF several times in order to remove moisture and demagnetize the coil.
- 2) STATUS CHECK OF HIGH VOLTAGE SUPPLY BOARD During the second stage of the Self-Test, SGIEC-645 will check the operational status of the high voltage (HV) supply board. If a problem is sensed, system will halt and status message will be displayed. If no problem is found, self-test will continue with next step.
- 3) SAFETY INTERLOCK STATUS CHECK The last stage of the Self-Test will check for a closed loop (short circuit) across the safety interlock port. If an open circuit is sensed, system will halt until safety interlock has been replaced. If short circuit is sensed, self-test will be completed.

After successful completion of the self-test, the following high-voltage warning appears on the display.



Press the \checkmark button, followed by the \checkmark button to acknowledge this high-voltage warning.

SECTION 6 - CONTROLLING THE SGIEC-645 VIA ITS FRONT PANEL

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

6.3 Quick Menu Access Option

After acknowledgement of the high-voltage warning, the following screen will appear on the display:



The default selection for this screen is NO. Pressing \checkmark without changing the selected option will take you to the SURGE SETUP MENU SCREEN (Section 6.4).

The QUICK MENU contains any previously saved surge setups. To access this menu, from the above screen, press the \leq button to change the selection from NO to YES, and press \checkmark . The QUICK MENU will be displayed:



To access the QUICK MENU from the SURGE SETUP MENU screen, press the button to reach the QUICK MENU ACCESS OPTION screen, press the change the selection from NO to YES, and press the button.

Up to ten (10) surge setups can be stored (see section 6.4), which can be accessed from this menu. Use the 1 and 1 buttons on the control pad to scroll through the stored surge setups (TASKS). Pressing the 1 button will allow the user to view the selected surge setup:

SURGE	SURGE SOL	JRCE EUT
WAVEFORM CC	DUPLING IMPED	DANCE POWER
1.2/50 A	U X 0	2Ω RDY
0200V X	0 1 1 / 0	20sec.
+ A - B	Ø R N D / N	A
← - RETURN	4 -	SELECT
GENERATOR	SURGE	TIME TILL
STATUS	COUNT	NEXT SURGE

Press the dutton to select this surge setup, and return to surge setup screen with these settings. Press the dutton to return to the QUICK MENU.

```
SECTION 6 - CONTROLLING THE SGIEC-645 VIA ITS FRONT PANEL

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917
```

6.4 Surge Setup Menu Screen

From this menu, the user is able to:

- a) select the desired the SURGE WAVEFORM;
- b) select surge generator output port to which the surge will be coupled (SURGE COUPLING);



- c) select the desired SOURCE IMPEDANCE value for the generator;
- d) monitor the EUT POWER state;
- e) set the **SURGE OUTPUT VOLTAGE** level for the surge event;
- f) set the NUMBER OF SURGES to be applied;
- g) set the TIME BETWEEN SURGES;
- h) set the desired COUPLING MODE and SURGE POLARITY;
- i) enable/disable **PHASE SYNCHRONIZATION** (applying the surge at a specific phase angle of the AC power line);
- j) set the PHASE SYNCH ANGLE;
- k) RUN the surge test using the defined surge parameters; and,
- I) **SAVE** the Surge Setup, so that it can be accessed later from the Quick Access Menu (see section 6.3)

Each of these functions are explained in detail in the following sections.

Illustrated in Figures 16 through 18 are the available menu options for surge output parameters for both the 1.2/50 μ s and 10/700 μ s Combination Wave Surges, respectively.



FIGURE 16 - Surge Waveform Selection on Surge Setup Menu

SECTION 6 - CONTROLLING THE SGIEC-645 VIA ITS FRONT PANEL 19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u> REV071917



Page 44 of 76 INSTRUCTION MANUAL SGIEC-645 COMBINATION WAVE SURGE GENERATOR







FIGURE 18 - Summary of Surge Parameter Options for 10/700 µs Wave SECTION 6 - CONTROLLING THE SGIEC-645 VIA ITS FRONT PANEL 19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



6.4.1 Surge Setup Menu Navigation/Operation

On the surge setup menu screen, the user has the ability to modify any of the surge parameter fields which are highlighted / highlighted in the diagram to the



right using the blue control panel arrow/function buttons located on the front panel, to the right of the display (shown above).

Pressing the Dutton at any time will begin the test.

Pressing the **I** button at any time will save the current surge setup to memory, which can be accessed at any time by using the QUICK MENU.

6.4.1.1 Menu Navigation

By default, the SURGE WAVEFORM field is selected on this menu. On the above diagram, the fields are numbered in the order of selection. Whenever the d button is depressed, the next field is selected. When the discrete is depressed, the previous field is selected.

6.4.1.2 Modifying Non-Numeric Surge Parameter Fields

When any highlighted (non-numeric) field is selected is selected, the user can scroll through the available options for that field using the 1 and 1 buttons. Press the 1 button once the desired option is selected. This will program your selection, and the next field on the menu will now be selected.

6.4.1.3 Modifying Numeric Surge Parameter Fields

When any highlighted (numeric) field is selected, the user can modify the numeric value as shown below:

Use the **1** keys to increment/decrement the value of the selected digit (0-9). Use the **-** keys to switch between selected digit as illustrated below.

1		1		1
0	←	0	←	1
¥		\		¥

Press the desired value is entered. This will program your selection, and the next field on the menu will now be selected.

SECTION 6 - CONTROLLING THE SGIEC-645 VIA ITS FRONT PANEL

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



6.4.2 Surge Setup Menu Items

6.4.2.1 Surge Waveform

The SURGE WAVEFORM field contains two defined combination waveforms, as

SURGE WAVEFORM	SURGE COUPLING	SOURCE	EUT POWER
1 . 2 / 5 0 0 2 0 0 V X + A - B ► - R U N	AUX 011 ØRND J-0K	02Ω /020s /NA ■-S	R D Y e C . A V E
GENERATOR STATUS	SURG		ME TILL KT SURGE

shown below. Use the 🚹 🛃 buttons on the front panel to toggle through the available options:

Options	Description
1.2/50	1.2/50 µs, 8/20 µs Combination Wave Surge
10/700	10/700 µs, 5/320 µs Combination Wave

When the desired SURGE WAVEFORM is displayed, press the button to enter your selection.

6.4.2.2 Surge Coupling

The SURGE COUPLING field allows the user to select the surge output port. Use the to buttons on the front panel to toggle through the available options:



Options	Description	Availability
AUX	Auxiliary Output Port	1.2/50 & 10/700 Waveforms
INT1Ø	Int. CDN Output Port	1.2/50 Waveform only
EXT1Ø	Ext. 1Ø CDN	1.2/50 Waveform only
EXT3Ø	Ext. 3Ø CDN	1.2/50 Waveform only

When the desired SURGE COUPLING selection is displayed, press the \checkmark button to enter your selection.

6.4.2.3 Source Impedance

The SOURCE IMPEDANCE field allows the user to select the surge generator output impedance. Use the to buttons on the front panel to



toggle through the available options:

Options	Description	Availability
02Ω	2 Ω Source Impedance	1.2/50 Waveform only
12Ω	2Ω +10 Ω Source Impedance	1.2/50 Waveform only
40Ω	40 Ω Source Impedance	10/700 Waveform only
15Ω	15 Ω Source Impedance	10/700 Waveform only

When the desired SURGE COUPLING (output port) is displayed, press the dutton to enter your selection.

SECTION 6 - CONTROLLING THE SGIEC-645 VIA ITS FRONT PANEL

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>



6.4.2.4 Surge Output Voltage

The SURGE OUTPUT VOLTAGE field allows the user to enter the peak voltage of the surge.



The output voltage can be set to any value between 200 and 4000 Volts.

Refer to section 6.4.1.3 for instructions to enter the voltage value.

When the desired SURGE OUTPUT VOLTAGE is displayed, press the desired surger your selection.

> SURGE WAVEFORM

6.4.2.5 Number of Surges

The NUMBER OF SURGES field allows the user to enter the number of times that the surge will be applied.

 1 . 2 / 5 0
 A U X
 0 2 Ω
 R D Y

 0 2 0 0 V
 X
 0 1
 1 / 0 2 0 s e c .

 + A
 - B
 Ø R N 0 * / N A

 ► - R U N
 J - 0 K
 ■ - S A V E

 GENERATOR
 SURGE
 TIME TILL

 STATUS
 COUNT
 NEXT SURGE

SURG

COUPLING

SOURCE IMPEDANCE

POWER

The number of surges can be set to any value from 1 and 99.

Refer to section 6.4.1.3 for instructions to enter the number of surges.

When the desired NUMBER OF SURGES is displayed, press the button to enter your selection.

6.4.2.6 Time Between Surges

The TIME BETWEEN SURGES field allows the user to enter the time interval between consecutive surges.



The minimum time between surges depends on the SURGE WAVEFORM that is selected, due to varying charge times.

For the 1.2/50 waveform, the **minimum time** between surges is 20 seconds.

For the 10/700 waveform, the **minimum time** between surges is 35 seconds.

The **maximum time** between surges for both the **1.2/50** and **10/700** waveforms is 600 seconds.

Refer to section 6.4.1.3 for instructions to enter the time between surges.

When the desired TIME BETWEEN SURGES is displayed, press the United button to enter your selection.

SECTION 6 - CONTROLLING THE SGIEC-645 VIA ITS FRONT PANEL

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



6.4.2.7 Coupling Mode

The COUPLING MODE field allows the user to select the output port terminals onto which the surge(s) will be applied, as well as the polarity of the surge.



The available options for coupling mode will depend on the surge waveform, output port, and source impedance selections.

Please refer to Figures 17 and 18 for a list of available options in any given scenario.

Use the 1 buttons on the front panel to toggle through the available options.

When the desired COUPLING MODE is displayed, press the desired button to enter your selection.

6.4.2.8 Phase Synchronization Angle/Reference

This field allows the user to enable/disable synchronization of the surge to a specific phase angle of the AC power for the lines being surged.



This phase synchronization

feature is only available when the SURGE WAVEFORM selected is 1.2/50 and the SURGE COUPLING selection is either INT1Ø, EXT1Ø or EXT3Ø.

If the SURGE COUPLING selection is **AUX** (for either surge waveform), only the default option of **RND^o/NA** is available.



Please refer to Figure 17 for a list of the available options for this field. Use the **1** buttons on the front panel to toggle through the available options.

When the desired **PHASE SYNCHRONIZATION ANGLE/REFERENCE** is displayed, press the dutton to enter your selection.

SECTION 6 - CONTROLLING THE SGIEC-645 VIA ITS FRONT PANEL 19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>



6.4.2.9 Run Test

Pressing at any time on this menu screen will start the test with the presently defined parameters.





The screen to the left will be displayed while the generator charges. The counter at the bottom right corner will count down to 0:00.

After charging, the following screens will be displayed; the first indicating that the high voltage is ready for discharging, and the second indicating that the surge is being applied.



After the surge has been applied (and assuming that there is only one surge to be applied), there will be a 5 second delay (shown on the screen below), followed by the next screen, indicating completion of the test.

SURGE SURGE SOURCE EUT WAVEFORM COUPLING IMPEDANCE POWER	SURGE S WAVEFORM CO	SURGE SOURCE EUT
1.2/50 AUX 020 ON 0200V X 01 1/020 sec. +A -B ØRND/NA DELAY 5 s 1/1 0:00	1 . 2 / 5 0 A 0 0 2 0 0 V X 0 + A - B 6 C 0 M P L E T E 0	JX 02Ω 0N 01 1/020sec. ØRND/NA 0 1/1 0:00
GENERATOR SURGE TIME TILL STATUS COUNT NEXT SURGE	GENERATOR	SURGE TIME TILL COUNT NEXT SURGE

After completion of the test, press the $rac{40}{5}$ button to return to the SURGE SETUP MENU screen.

6.4.2.9.1 Pausing the Test

At any point during the test, pressing the 📶 key will immediately pause the current process and "PAUSED" will be displayed as the generator status.

The test will remain paused until the test is resumed by pressing the 🕨 key.

6.4.2.9.2 Aborting the Test

At any point during the test, pressing the **1** key will immediately abort the test process and "ABORTED" will be displayed as the generator status.

After aborting the test, press the 📶 key to return to the Surge Menu.





6.4.2.10 Save Test

Pressing at any time on the SURGE SETUP MENU screen will save the presently defined parameters into one of the ten available non-volatile memory locations.





If there is at least one empty memory slot remaining, the screen to the left will be displayed, which will indicate the memory slot into which the surge setup is saved.

If there are no memory slots available, the screen to the right will be displayed. Selecting the NO option will return you to the setup screen without saving. If you select the YES option, the following screen will be displayed:

SURGE WAVEFORM	SURGE COUPLING		POWER
MEN DOY REPLACE YES	IORY F YOU WA E OLD	ULL NT TC ENTRY) 7 ? N O
GENERATOR STATUS	SURG		IME TILL XT SURGE



memory slot to overwrite with the surge setup you are currently saving, and the following message will be displayed:

Use the 1 buttons to navigate through the list of previously saved surge setups (TASKS). Press the **1** button to cancel the operation, and you will be returned to the setup screen. Press the **2** button to select the



SECTION 6 - CONTROLLING THE SGIEC-645 VIA ITS FRONT PANEL

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917



7.0 TransWare-645[™] Software

7.1 Main Screen

The layout of the main screen is as shown in Figure 19.



FIGURE 19 - Main Screen – TransWare-645™ Software



SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.1 Menu Bar

The menu bar is occupied by three menus:

- 1) FILE menu (refer to section 7.1.1.1)
- 2) CONNECT DEVICE menu (refer to section 7.1.1.2)
- 3) **HELP** menu (refer to section 7.1.1.3)

7.1.1.1 File Menu

The **FILE** pull-down menu contains the following options:



MENU ITEM DESCRIPTION

New Sequence	Upon creation of a new sequence, <i>TransWare-645™</i> will prompt you to save any active sequence before opening a blank template on which you can create your desired sequence.
Load Sequence	Opens dialog box from which the user can navigate directory system in order to open a previously saved test sequence (with .cpc extension).
Save Sequence	This function re-saves the sequence under the current file name and directory path.
Save As	Opens dialog window from which the user can navigate directory system, assign a file name and save the active test sequence (with .cpc extension).
Print Sequence	Opens the 'print' dialog window, from which the user can print the active test sequence.
-	If the sequence has previously been saved, the file name under which the sequence was saved is used as the title of the sequence table. If the sequence has not been saved, the user is prompted to assign a title for the sequence table.
Exit	After prompting the user to save changes to any active sequence; exits the TransWare-645 [™] software.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.1.2 Connect Device Menu

The **Connect Device** option is the only option for this menu.

DESCRIPTION MENU ITEM **Connect Device** Initiates connection process between computer and SGIEC-645 Surge Generator. The TransWare-645[™] software will scan the communication ports and engage connection upon recognition of a compatible generator. When the connection has been made, the Communication status at the bottom left corner of the TransWare-645[™] window will change from: Communication : DISCONNECTED LOCAL to: Communication : CONNECTED REMOTE

This indicates that the unit is in its remote operating mode. In this mode, all the front panel controls on the generator itself are disabled, with the exception of the EUT power switch.

7.1.1.3 Help Menu



The *Help* menu contains the following options:

MENU ITEM	DESCRIPTION
Manual	Opens a pdf copy of the present manual.
Com-Power Home Page	Opens the computer's default internet brower to the following URL:
•	http://www.com-power.com.
About	Opens a small window showing a short description of the TransWare-645 TM software, including version and copyright information.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.2 Tool Bar





7.1.3

3

Sequencing Panel

The sequencing panel contains all of the individual surge events in the test sequence. If a sequence has not yet been created, the sequencing panel is blank, as shown below.

Enter Tasks To Continue (Edit Sequence > Add)

Adding, removing and editing surge events is done using the SEQUENCE EDITING FUNCTIONS, which is accessed by selecting the EDIT SEQUENCE option on the TASK OPTIONS panel (see section 7.1.4). Surge events are displayed in table format as shown below, with each surge event displayed on a single row.

	Pause	message	vvaweturm	Coupling	impedance	vonage	#Tests	Oulput reminais	Polanty	Phase Reference	Avrigite (1)	interval (sec.)	Enable	Status
1			1.2/50us	Internal 1-Phase	12E	500	5	Internal (L - PE)	Positive (+)	L-PE	0	60		
2			1.2/50us	Internal 1-Phase	12E	500	5	Internal (L - PE)	Positive (+)	L-PE	0	60		
3			1.2/50us	Internal 1-Phase	12E	500	5	Internal (L - PE)	Negative (-)	L-PE	90	60		
4			1.2/50us	Internal 1-Phase	12E	500	5	Internal (L - PE)	Negative (-)	L-PE	90	60		
5			1.2/50us	Internal 1-Phase	12E	500	5	Internal (L - PE)	Positive (+)	L-PE	180	60		
6			1.2/50us	Internal 1-Phase	12E	500	5	Internal (L - PE)	Positive (+)	L-PE	180	60		
7			1.2/50us	Internal 1-Phase	12E	500	5	Internal (L - PE)	Negative (-)	L-PE	270	60		
▶ 8			1.2/50us	Internal 1-Phase	12E	500	5	Internal (L - PE)	Negative (-)	L-PE	270	60		

Each column in the table corresponds to a separate, user-definable test parameter for each surge event. These test parameters are defined in the following section (7.1.3.1).

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.3.1 User-defined Surge Test Parameters

	USER-DEFINED TEST PARAMETERS
STREET ST	WindowCoupleWayeWindowCoupleWayeWindowKayeWaye<
TEST PARAMETER	DESCRIPTION
Pause	A check in this check box instructs the SGIEC-645 to pause the test prior to that surge event and display a message box
	with a pre-defined message to the user. Upon acknowledgement of message, the test sequence automatically continues.
Message	This is the message associated with the PAUSE check box. When the PAUSE check box is checked, the message editor automatically opens, enabling the user to either create a new message; or assign an existing message to appear in the message box when the sequence reaches the present surge event. No message can be assigned if the pause box is not checked.
Waveform	This (2) item pull-down menu is used to select the waveform for a given surge event.
Coupling	This (4) item pull-down menu is used to select the surge output port to which the surge will be coupled
Impedance	This (2) item pull-down menu is used to select the source impedance of the surge generator.
Voltage	This is a numeric entry field for setting the open circuit output voltage of the surge event. It may be set to any value between 200V and 4000V.
# Tests	This is a numeric entry field for setting the number of times this surge will be applied.
Output Terminals	This pull-down menu is used to select the specific output port terminals to which the surge(s) will be applied.
Polarity	This (2) item pull-down menu toggles the polarity of the surge between POSITIVE and NEGATIVE.
Phase Reference	This pull-down menu is used to select the phase reference terminals for phase synchronization, or to select RND (random), where no phase synchronization is to be used.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



This is a numeric entry field for setting the phase angle of the Angle (°) AC line at which the surge will be discharged. It may be set to any angle from 0 to 359 degrees; or RND (random/arbitrary) when no phase synchronization is to be used. Interval (sec.) This is a numeric entry field for setting the time between surges. It may be set to any value from 20 seconds (for the 1.2/50 waveform); or 35 seconds (for the 10/700 waveform) up to 600 seconds. When checked, the present surge event is enabled. When Enable unchecked, the surge event is disabled. Disabled events are skipped during the test. The status column displays the generator status while the test **Status** is running (discharging, charging, waiting, etc.)



Task Options Panel

The functions available on the within this panel change depending on which of the two main functions is selected. Initially the TASK OPTIONS panel contains two buttons:

EDIT SEQUENCE	
LOGGING OPTIONS	

Pressing the **EDIT SEQUENCE** button will reveal the SEQUENCE EDITING FUNCTION buttons, used for creating/editing test sequences in the sequencing panel (see section 7.1.4.1); as well as the SEQUENCE WIZARD button, which opens the sequence wizard in a separate window (please refer to section 7.1.5).

Pressing the **LOGGING OPTIONS** button will reveal the in-test observation logging (please refer to section 7.1.4.2).

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.4.1 Sequence Editing Functions



The sequence editing functions are displayed on the TASK OPTIONS panel after selecting **EDIT SEQUENCE** on the TASK OPTIONS menu.

Using these functions, the user can create and edit test sequences displayed in the sequencing panel.

FUNCTION BUTTON	DESCRIPTION
Cut ¹	Cuts (removes) the selected surge events(s) from the sequence.
	The cut surge event(s) are then kept in the QUEUE (aka: clipboard). ²
Copy ¹	Copies the selected surge event(s) in the sequence. The copy of the surge event(s) are then kept in the QUEUE.
Paste ¹	Pastes the surge event(s) currently in the QUEUE directly above the selected task.
Add	Adds a surge event with default values at the end of the active sequence.
Insert ¹	Inserts a surge event immediately above, and with identical values to, the selected surge event.
Remove ¹	Removes the selected surge event(s) from the sequence.
Move Up ¹	Moves the selected surge event(s) upward by one row in the sequence.
Move Down ¹	Moves the selected surge event(s) downward by one row in the sequence.
Remove All	Removes ALL surge event(s) from the sequence.
Message Editor ³	Opens the MESSAGE EDITOR, where you can edit, delete and assign messages associated with the pause function on the surge event(s).
Done	Exits the SEQUENCE EDITOR and returns to the to the TASK OPTIONS MENU.
In order for the CUT, functions to be active numbered column to t	COPY, INSERT, REMOVE, MOVE UP or MOVE DOWN e, surge event(s) must be selected by clicking the he left of the sequence for the desired event(s).
2	

- ² The QUEUE is used to temporarily store CUT or COPIED surge event(s) pending a PASTE action. The QUEUE will only store surge event(s) from a single CUT or COPY action. Any item(s) held in the queue prior to an additional CUT or COPY action are discarded.
- ³ The MESSAGE EDITOR function is only active after selecting the MESSAGE column of any surge event.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.4.2 Logging Options

The IN-TEST OBSERVATION LOGGING functions are displayed on the task options panel after selecting LOGGING OPTIONS on the TASK OPTIONS menu.

comments into, the test log.

Create Test Log	OBSERVATION LOGGING View Test Log Exit Logging A	rea
Enter Comments, EU	IT Observation Notes Test Results	*
etc. d	luring the active test.	

Here, the user can create a test log; edit, view, and enter

FUNCTION BUTTON DESCRIPTION

Create Test Log

Opens a form window with fields for Company Name, Cognizant Company Representative, Equipment Under Test, Test Operator, Comment and File Path.

lest Log Information		
Company Name		
ACCUTEST SYSTEMS PVT. L	TD	
Cognizant Company Represe	ntative	
Sagar Patel		
Equipment Under Test		
SCOPE		
fest Operator		
Jay Bhatt		
Comment		
EUT under test		< >
fest log file Destination/File N	lame	wse

After filling out the form, click the BROWSE button, which will open another window.

TransWare-168 Save Sequence					×
🔾 🖯 = 🔳 Desktop 🔸		•	4 Search		Q
🐚 Organize 👻 🔡 Views 💌 📕	👔 New Folde		_	_	0
Favorite Links	Name	Size	Type	Date modified	
Recently Changed	100	Cam Barrar			
M Desktop		ComPoner			
3 Recent Places					
Second Computer		Public			2
Documents					
Pictures		Computer			
Music	100				
P Searches		Network			
Public Public	-				
Folders	• <u> </u>	Datasheets (old) File Folder			
File name:					•
Save as type: (.xls) (*.xls)					-
Hide Folders				Save Cano	el .

In this window, navigate to the desired directory, assign a file name and click save.

Finally, click the CREATE button to finish the process.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>



After creating the test log, the IN-TEST OBSERVATION LOGGING functions are as shown to the left and described below.

Exit Logo	Test Log	Are:
	-	
otes, Test Res est.	Comments, EUT etc. du	



FUNCTION BUTTON

View Active Test

DESCRIPTION

Opens the active log form displaying entered comments and surge details.

P activ	ve_log	-	×
	Surge Details	Comments	
	Waveform/Voltage : Type A / 800 Polarity : Positive (+) Surge Output : Terminals (A - B) #Tests : 1 Interval : 74	STARTED AT - November 18, 2015 [03:01:40 AM]	

Enter Comments Allows the user to enter notes or comments (up to 250 characters) before and/or during Into Log the test. The intent of this feature is allow the test engineer to record EUT observations, such signs of susceptibility, unintended as operations, malfunctions, etc., as they occur during the course of the test. Comments are stamped with the exact time/date at which they were entered. The completed test log lists all entered comments chronologically with relation to the corresponding surge event at the time the comment was entered. Exit Logging Area Closes the logging functions and returns to the TASK OPTIONS MENU.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.5 Sequ

5

Sequence Wizard

The sequence wizard is used to quickly and intuitively create all types of surge test sequences; from the most basic sequence with only a few surges to long, complicated sequences with several hundred separate surge events.

The sequence wizard seamlessly incorporates the ability to create sequences based on the most recent changes to the IEC 61000-4-5, as well as sequences based on older versions of the standard.

P Sequence Wizard			- • 💌
5a <u>Surge Waveform</u> 1.2/50us	5b <u>Coupling</u>	5C <u>Test Time</u> Click 'HERE' to calcuate Test Time	1.2 / 50us Surge Waveform @ Internal CDN <u>Coupling Modes</u>
5d <u>EUT Power Configuration</u>	5e <u>Coupling M</u>	odes	Source Impedance
1P with PE (3 conductors) • 5f Source Impedance	L - PE N - PE N - PE ADD REMOVE		- Auto 2E / 12E
5g <u>Test Voltage(s)</u>	5h) Phase Synchronization	5i <u>Polarity</u>	Phase Sync Angle
Make Incremental List Volts: 500 V	ON / OFF ON 5j Make Incremental List	Alt 1 Each Number of Surges Surges	Polarity
Add REMOVE	Increment: 90 • • 5k	Time Between Surges 60 seconds Sequence Order Priority	AICT Each <u>Number Of Surges</u> 5 Time Between Surges
DO NOT apply differential mode surges greater than 1000 V	Do not use Phase synch. for surges applied between N and PE	1) Polarity 2) Phase Angle 3) Coupling Modes 4) Votage Level Move DOWN 5	n Preview Sequence Create Sequence 50

Shown below is a screen shot of the sequence wizard window:

FIGURE 20 - Sequence Wizard Screen

Each of the individual functions **(5a through 5o)**, are described in detail in the following sections, including instructions/guidance.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917

Page 61 of 76



SGIEC-645 COMBINATION WAVE SURGE GENERATOR

7.1.5.1 Surge Waveform

The SURGE WAVEFORM field contains two defined combination waveforms, as shown below. Use the pull-down menu to select the desired waveform from the following options:

1.2 / 50us	•
1.2 / 50us	
10 / 700us	
107700us	

Surge Waveform

Options	Description
1.2/50	1.2/50 µs, 8/20 µs Combination Wave Surge
10/700	10/700 µs, 5/320 µs Combination Wave

7.1.5.2 Coupling

5a

5b

The COUPLING field allows the user to select the surge output port. Use the pull-down menu to select the surge output port (COUPLING) from the following options: Coupling

Internal CDN	-
Internal CDN	
External 1-Phase CDN [via Aux]	
External 3-Phase CDN [via Aux]	
Auxiliary	

Description	Availability
Internal CDN	1.2/50 Waveform only
External 1P CDN [via Aux]	1.2/50 Waveform only
External 3P CDN [via Aux]	1.2/50 Waveform only
Auxiliary	1.2/50 or 10/700 Waveforms

7.1.5.3 Test Time

Pressing the "Click 'HERE'..." button at any time will calculate the test time based on the present selections/entries on the wizard screen. Any changes made to to

Test Time

3 Hours 50 Minutes

And 0 Seconds

Test Time

Click 'HERE' to calcuate Test Time

the wizard selections/entries after the test time has been calculated will cause the previously calculated test time to be replaced by the original "Click 'HERE'..." button.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917

Distributed by: Reliant EMC LLC, +1 408 916 5750, info@reliantemc.com, www.reliantemc.com



5c



5d)

7.1.5.4 EUT Power Configuration

modes for the test.

The EUT Power Configuration menu is used to select the type of power system used by the EUT in order to determine the available coupling EUT Power Configuration

 1P with PE (3 conductors)

 1P with PE (3 conductors)

 1P w/o PE (2 conductors)

 DC w/o PE (2 conductors)

 DC with PE (3 conductors)

The table below summarizes the

available options and their availability based on the SURGE WAVEFORM and surge generator output port (COUPLING) selected.

Use the pull-down menu to select the applicable EUT power configuration.

Options	Description	Availability
1 Phase	Single phase AC power	
with PE	system WITH 3 rd -wire GND	
(3 conductors)		
		1.2/50 Waveform only
1 Phase	Single phase AC power	-Internal CDN
w/o PE	system W/O 3 rd -wire GND	-External 1-Phase CDN
(2 conductors)		[via Aux]
DC w/o PE	DC power system	
(2 conductors)	W/O 3 rd -wire GND	
DC with PE	DC power system	
(3 conductors)	WITH 3 rd -wire GND	
3-Phase	Three phase WYE	1.2/50 Waveform only
WYE	AC power system	OUTPUT PORT:
(5 conductors)	(3 Lines, Neutral, GND)	-External 3-Phase CDN
3-Phase	Three phase DELTA	[via Aux]
DELTA	AC power system	
(4 conductors)	(3 Lines, GND)	
Aux [via A-B]	Auxiliary (A/B) Output	1.2/50 or 10/700 Waveform
	Terminals	OUTPUT PORT:
		Auxiliary

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.5.5 Coupling Modes



The COUPLING MODES represent the surge generator output port terminals to which the surges will be applied.

The available coupling modes will vary depending on the SURGE WAVEFORM, selected output port (COUPLING) and EUT POWER CONFIGURATION.

Available options are always listed in the window to the left of the add/remove buttons. Please refer to Figures 18 and 19 for a complete list of available coupling modes for any given scenario.

The coupling modes added to the test sequence by the user are displayed in the window to the right of the add/remove buttons.



Pressing the **ADD all** button will add all the available coupling modes shown in the left window to the test sequence.

Pressing the **ADD** button will add the selected coupling mode(s) within the left window to the test sequence.

Pressing the **REMOVE** button will remove the selected coupling mode(s) in the right window from the test sequence.

Pressing the **REMOVE all** button will remove all coupling modes listed in the right window from the test sequence.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.5.6 Impedance



The IMPEDANCE pull-down menu allows the user to select the surge generator output impedance. Source Impedance

Auto 2E / 12E Auto 2E / 12E

The table below summarizes the available options and their availability based on the surge generator output port (COUPLING) selected.

Use the pull-down menu to select the surge desired output impedance from the following options:

Options	Description	Availability
2E	2Ω Source Impedance	1.2/50 Waveform only
		Auxiliary Output only
Auto 2/12E	2 Ω Source Impedance	1.2/50 Waveform only
	(for Line to Line Surges)	ALL Output Ports
	$2\Omega + 10\Omega$ Source Impedance	except Auxiliary
	(for Line to Ground Surges)	
40E	40 Ω Source Impedance	10/700 Waveform only
		Auxiliary Output only
15Ω	15 Ω Source Impedance	10/700 Waveform only
		Auxiliary Output only

7.1.5.7 Test Voltage(s)



The test voltage(s) panel allows the user to define the surge test voltage(s) to be included in the sequence.

Test voltage(s) can be added one at a time as described in section 7.1.5.7.1.

By checking the "Make Incremental List" checkbox in the TEST VOLTAGE(s) panel, the user is able to define start, stop, step or delta values to define the test voltages for the test as described in section 7.1.5.7.2.

When applying surges to power lines, it is not uncommon to have higher test levels specified for line to ground (commonmode) surges than those specified for line to line (differential mode) surges.

Using the TransWare-645TM software, this problem can be eliminated by simply checking a checkbox and typing a voltage value. Please refer to section 7.1.5.7.3 for further instructions.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.5.7.1 Creating Test Voltage(s) List from Discrete Values

Individual, discrete voltage values can either be typed into the "Volts:" box, or the existing value may be increased/decreased in 50 Volt increments using the up/down arrow buttons on the right side of the box.

Press the Add button to add the value to the list box on the right.

Press the **REMOVE** button to remove the selected value from the list box on the

7.1.5.7.2 Creating Test Voltage(s) List using an Incremental List

By checking the "Make Incremental List" checkbox, the user may configure incremental lists of test voltages to be applied as part of the surge test sequence.

The start and stop voltages can either be typed into the respective boxes, or the existing value may be increased/decreased in 50 Volt

increments using the up/down arrow buttons on the right side of each box.

After defining the start and stop voltages for the list, the user can specify either the number of steps, or the step voltage (delta). If the number of steps is changed, the delta will automatically be recalculated. If the delta is changed, the number of steps will automatically be recalculated.

An example of an incremental test voltage list is given in the above illustration.

Press the **CREATE** button to add the incremental list values to the test voltage(s) list.

Press the **REMOVE** button to remove the selected value from the list box on the right.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917

lest voltage	(5)
Make Incremental List	
Volts: 500 🛓 V	
Add	REMOVE
DO NOT apply differen	tial mode
surges greater than 1	000 V

👿 Make Incremental List

CREATE

Start: 500

Stop: 2000

Delta: 500

Steps: 3

1000

1500 2000

REMOVE

🔶 V

🔶 V

DO NOT apply differential mode

surges greater than 1000 V

the selected value from the list box on the right.
Creating Test Voltage(s) List
Test Voltage(s)



7.1.5.7.3 Common Mode vs Differential Mode Surge Test Levels

Most product family standards, generic product environment standards, etc., specify higher surge voltage levels for Line to Ground (Common Mode) than those specified for Line to Line (Differential Mode) Surges

For convenience, rather than having two separate test voltage lists, there is checkbox/entry field at the bottom of the Test Voltages

DO NOT apply differential mode surges greater than 1000 V

section of the wizard which allows the user to specify the highest surge voltage to be applied in differential mode.

For instance, if the test is to be performed at surge voltages of 0.5, 1 and 2 kV for common mode, but only 0.5 and 1 kV for differential mode; all three voltage values can be added to the list. In order to avoid having the 2 kV surges applied to the differential mode surges, the user can simply check the "**DO NOT apply differential mode surges greater than**", checkbox, and then enter "**1000**" (V) in the associated entry field.

In this scenario, the 0.5 kV and 1 kV surges will be applied for both common mode and differential mode coupling modes, while 2 kV surges will only be applied for common mode surges.

SECTION 7 - TRANSWARE-645™ SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917



Page 67 of 76 INSTRUCTION MANUAL SGIEC-645 COMBINATION WAVE SURGE GENERATOR

7.1.5.8 Phase Synchronization

5h

Phase synchronization applies only for tests performed using the **1.2/50** surge waveform applied to AC power lines via the internal or external power line CDN.

In these cases, when Phase Synchronization is turned ON, the application of the surges is initiated at the user-specified phase angle $(0-359^{\circ} \pm 10^{\circ})$ of the referenced lines of the AC power line. For example, a 1 kV surge applied at the 90



degree phase angle of the 230 VAC referenced lines would appear as shown below:



If phase synchronization is turned OFF, the surges are applied arbitrarily, or randomly (RND).

Phase synch angles can be added one angle at a time as described in section 7.1.5.8.1.

By checking the "Make Incremental List" checkbox in the PHASE SYNCHRONIZATION panel, the user is able to create the list of phase angles as described in 7.1.5.8.2.

It is stated in the IEC 61000-4-5, Edition 3.0 standard, that phase synchronization is to be applied for surges applied between Neutral and Earth conductors; which directly contradicts all previous versions of the same standard. Please refer to section 7.1.5.8.3 for instructions and guidance regarding this new policy.

With the exception of Neutral to Earth Surges with phase synch, the AC phase reference for phase synchronization is the voltage between the lines to which the surge is being coupled.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917



7.1.5.8.1 Creating Phase Angle List using Discrete Values

Phase Synchronization
ON / OFF ON
Make Incremental List
Angle: 90 🖕 오
ADD REMOVE
Phase Ref. Surged Lines (+) to (-)
Do not use Phase sync. for surges applied between N and PE

Individual, discrete phase angle values can either be typed into the "Angle:" box, or the existing value may be increased/decreased in 5 degree increments using the up/down arrow buttons on the right side of the box.

Press the Add button to add the phase angle value to the list box on the right.

Press the **REMOVE** button to remove the selected phase angle value from the list box on the right.

Phase Synchronization

90

180

270

REMOVE

ON

📝 Make Incremental List

CREATE

Phase Ref. Surged Lines (+) to (-)

Do not use Phase sync. for

surges applied between N and PE

Increment: 90

7.1.5.8.2 Creating Phase Angle List using Incremental List

By checking the "Make Incremental List" checkbox, the user may configure an incremental list of phase angles to be applied as part of the surge test sequence.

The phase angle increment can either be typed into the "Increment:" box, or the existing value may be increased/ decreased in 5 degree increments using the up/down arrow buttons on the right side of each box.

An example of an incremental

phase angle list is given in the above illustration. With 90 degrees defined as the increment, the incremental list will include 0, 90, 180 and 270 degree phase angles.

ON / OFF

After defining the phase angle increment, press the **CREATE** button to add the incremental list values to the phase angle list on the right.

Press the **REMOVE** button to remove any selected value from the list box on the right.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com



7.1.5.8.3 Phase Synch – N to PE Coupling Mode

In Edition 3.0 of the IEC 61000-4-5 standard, the following paragraph was added pertaining to the phase synchronization requirements when applying surges from Neutral to Protective Earth (N to PE):

"No synchronization is applied in case of absence of mains supply voltage between the coupled lines, e.g. between N and PE in TN-S power distribution systems. In this case, five positive impulses and five negative impulses shall be applied".

Based on the above, when performing tests according to IEC 61000-4-5, Edition 3.0, no phase synchronization is to be applied for N-PE surges.

Therefore, the checkbox at the bottom of the Phase Synchronization section should remain unchecked.

ENABLE Phase Synch for N-PE surges AC Phase Ref.: L (1Ø) / L1 (3Ø) (IEC 61000-4-5 Ed. 1.x/2.x methods)

However, as many product family standards contain dated references to the IEC 61000-4-5 standard, it is sometimes necessary to perform the tests according to the Edition 2.x, or even 1.x of IEC 61000-4-5.

In order to accommodate the previous editions of IEC 61000-4-



5, the user can check the checkbox at the bottom of the Phase Synchronization section, which will enable phase

synchronization for N-PE surges, using the AC phase reference of the LINE conductor (for single-phase systems); or the LINE 1 conductor (for three-phase systems).

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917



7.1.5.9 Polarity

5i

5j

The POLARITY pull-down menu allows the user to specify the polarity(ies) of each type of surge in the sequence, and/or whether the polarities will alternate sequentially.

Use the pull-down menu to select the desired polarity option. Each option is defined in the following table:

Alt 1 Each 🔹
Alt 1 Each
Positive & Negative
Positive ONLY
Negative ONLY

Polarity

Options	Description	
Alt 1 Each	For any given surge, a single positively polarized surge is applied, subsequently followed by the same surge, negatively polarized	
Positive & Negative	Applies both positively and negatively polarized surges of each type, which may or may not occur sequentially in the sequence, depending on the selected Sequence Order Priority (see section 7.1.5.12)	
Positive ONLY	Only positively polarized surges will be applied	
Negative ONLY	Only negatively polarized surges will be applied	

7.1.5.10 Number of Surges

The NUMBER OF SURGES field defines the number of times each surge event will be applied.

Number of Surges

5

Surges

If cases where the selected POLARITY option is **Alt 1 Each**; any given event will be applied in pairs; one with positive polarity, followed by one with negative polarity. If the entered Number of Surges is greater than one, this 'pair' of alternating polarity surges will then be repeated successively, until the number of surges has been completed, before proceeding to the next surge event.

The entered value can be any number between 1 and 99. The typical number of surges for tests according to any version of IEC 61000-4-5 is "5".

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



7.1.5.11 Time Between Surges



The TIME BETWEEN SURGES field defines the time interval between successive surge applications.

Time Between Surges

60 seconds

The minimum time between surges depends on the SURGE WAVEFORM that is selected, due to varying charge times.

For the **1.2/50** waveform, the **minimum time** between surges is **20 seconds**.

For the **10/700** waveform, the **minimum time** between surges is **35 seconds**.

The **maximum time** between surges for both the **1.2/50** and **10/700** waveforms is 600 seconds.

7.1.5.12 Sequence Order Priority



The SEQUENCE ORDER PRIORITY is a dynamic list of surge parameter categories which is used to determine the order of the final test sequence.

1) 2)	 Polarity Phase Angle Coupling Modes Voltage Level 	Move UP
3) 4)		Move DOWN

Sequence Order Priority

The order in which the surge parameter categories are listed may be modified by the user by selecting any one of the four in the list, and using the **MOVE UP** and/or **MOVE DOWN** buttons to move the selected event up or down in the list.

SECTION 7 - TRANSWARE-645™ SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917



Page 72 of 76 INSTRUCTION MANUAL SGIEC-645 COMBINATION WAVE SURGE GENERATOR

In the following example, the identical test sequence settings were used with four different Sequence Order Priority arrangements in order to illustrate its affects on the order of surge events in the sequence:



In Example SURGE SEQUENCE (A), for example, POLARITY is the first priority; therefore, the surge polarity will change after each surge event.

In the same example (A), VOLTAGE LEVEL is the second priority; therefore, the voltage level parameter will be the second item that will change. In this case, the voltage level changes after each (+)/(-) polarity. The coupling mode and/or phase angle will not change until each polarity and each voltage level has has been applied for the present coupling mode/phase angle.

The COUPLING MODE in the same example (A) is the third priority. Only after exhausting all possible polarities and voltage levels for the first coupling mode, the coupling mode will then change to the next coupling mode (assuming another exists).

And finally, for the same example (A) the fourth priority is the Phase Angle. Only after exhausting all possible polarities, voltage levels and coupling modes, the phase angle will then change to the next available setting (assuming another exists).

In examples (B) through (D), the same test sequence is reordered using the respective SURGE ORDER PRIORITIES listed at the top of each example.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917


5m)

Page 73 of 76 INSTRUCTION MANUAL SGIEC-645 COMBINATION WAVE SURGE GENERATOR

7.1.5.13 Sequence Wizard Surge Parameter Summary

The sequence wizard surge parameter summary, shown with a blue background and white text on the right side of the sequence wizard, summarizes all of the present surge parameters settings for the present sequence.



7.1.5.14 Preview Sequence Button



creates a tabular preview of the present settings in the sequence wizard, similar to the sequencing panel (section 7.1.3). An example of the sequence preview is shown below:

Preview Sequence 💿 🛛 🕰													
	Pause	Message		Coupling	Impedance		#Tests	Output Terminals	Polarity	Phase Reference	Angle (*)	Interval (sec.)	Enable
1			1.2/50us	Internal CDN	2E	500	1	L - PE	Positive (+)	L-PE	0	60	
2			1.2/50us	Internal CDN	2E	500	1	L - PE	Negative (-)	L-PE	0	60	
3			1.2/50us	Internal CDN	2E	1000	1	L - PE	Positive (+)	L · PE	0	60	
-4			1.2/50us	Internal CDN	2E	1000	1	L - PE	Negative (-)	L-PE	0	60	
-5			1.2/58us	Internal CDN	2E	500	1	N - PE	Positive (+)	L-PE	0	60	
6			1.2/50us	Internal CDN	2E	500	1	N - PE	Negative (-)	L-PE	0	60	
7			1.2/50us	Internal CDN	2E	1000	1	N - PE	Positive (+)	L · PE	0	60	
8			1.2/50us	Internal CDN	2E	1000	1	N - PE	Negative (-)	L-PE	0	60	
9			1.2/58us	Internal CDN	2E	500	1	L - PE	Positive (+)	L-PE	90	60	
10			1.2/50us	Internal CDN	2E	500	1	L - PE	Negative (-)	L · PE	90	60	
11			1.2/50us	Internal CDN	2E	1000	1	L - PE	Positive (+)	L - PE	90	60	
12			1.2/50us	Internal CDN	2E	1000	1	L - PE	Negative (-)	L-PE	90	60	
13			1.2/58us	Internal CDN	2E	500	1	N - PE	Positive (+)	L-PE	90	60	
14			1.2/50us	Internal CDN	2E	500	1	N - PE	Negative (-)	L-PE	90	60	
15			1.2/50us	Internal CDN	2E	1000	1	N - PE	Positive (+)	L - PE	90	60	
16			1.2/50us	Internal CDN	2E	1000	1	N - PE	Negative (-)	L-PE	90	60	
						Tel	al Teet	ima: 0 Hauna de Minutaa					
								ante. o Hours To minutes					
And 0 Seconds													

7.1.5.15 Create Sequence Button

Create Sequence



5n

The CREATE SEQUENCE button completes the sequence wizard operation and inserts the entire sequence into the sequencing panel (see section 7.1.3).

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>





Controls Panel

The CONTROLS panel is used to toggle EUT power and to start, pause and/or abort the surge test. Prior to starting the test, the controls area appears as shown to the right, and as described below.



FUNCTION BUTTON



DESCRIPTION

The EUT power button enables/disables the EUT power output on the internal CDN. The EUT power switches on the rear and front panels of the SGIEC-645 must also be in the 'ON' position in order to enable EUT power. Refer to section 4.1.2 for more information.

The PLAY button begins the test by Initiating the active test sequence.

While the test is running, the CONTROLS panel appears as shown to the right, and as described below.



MENU ITEM

DESCRIPTION

The PAUSE button pauses the active test. To resume the test from the point at which the test was paused, press the button again.



The STOP button aborts the active test. Test cannot be resumed after aborting.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>



switch to TEST STATUS view

Changes the TransWare-645[™] window to a smaller, compacted, repositionable window, while still providing access to all of the in-test features available with the larger window. This window will remain in front of all other open windows, enabling the user to work with other applications on the computer, while still monitoring the progression of the surge test. Logging functions are contained on a retractable logging subpanel of the TEST STATUS window, as shown below.



7.1.7

Remote Connection Status Bar

Please refer to sections 4.2.2.1 and 7.1.1.2.

SECTION 7 - TRANSWARE-645TM SOFTWARE

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • com-power.com

REV071917



8.0 Warranty

Com-Power warrants to its Customers that the products it manufactures will be free from defects in materials and workmanship for a period of three (3) years. This warranty shall not apply to:

- Transport damages during shipment from your plant.
- Damages due to poor packaging.
- Products operated outside their specifications.
- Products Improperly maintained or modified.
- Consumable items such as fuses, power cords, cables, etc.
- Normal wear
- Calibration
- Products shipped outside the United States without the prior knowlege of Com-Power.

In addition, Com-Power shall not be obliged to provide service under this warranty to repair damage resulting from attempts to install, repair, service or modify the instrument by personnel other than Com-Power service representatives.

Under no circumstances does Com-Power recognize or assume liability for any loss, damage or expense arising, either directly or indirectly, from the use or handling of this product, or any inability to use this product separately or in combination with any other equipment.

When requesting warranty services, it is recommended that the original packaging material be used for shipping. Damage due to improper packaging will void warranty.

If you feel that the product is not working as intended, or is malfunctioning, please contact Com-Power for assistance. If the product must be returned to Com-Power, a Return Merchandise Authorization (RMA) number will be supplied to you. The RMA number should be displayed in a prominent location on the packaging and on the product, along with a description of the problem, and your contact information.

SECTION 8 - WARRANTY

19121 El Toro Rd • Silverado, California 92676 • (949) 459-9600 • <u>com-power.com</u>

REV071917